

---

# **Nova Scotia Utility and Review Board**

**IN THE MATTER OF** *The Public Utilities Act*, R.S.N.S. 1989, c.380, as amended

## **2014 Integrated Resource Plan**

### **NS Power Final Report**

**October 15, 2014**

---

---

TABLE OF CONTENTS

1

2

3 1.0 EXECUTIVE SUMMARY ..... 5

4 2.0 INTRODUCTION ..... 11

5 2.1 2014 Integrated Resource Plan Process ..... 12

6 2.2 Advancements in the IRP Approach..... 13

7 2.2.1 Candidate Resource Plan (CRP) Approach ..... 14

8 2.2.2 Evaluation with Plexos ..... 14

9 2.2.3 Sustaining Capital Investments..... 15

10 2.3 Role of Board Staff and Consultants ..... 16

11 2.4 Stakeholder Consultation & Public Process ..... 16

12 2.4.1 Stakeholder Consultation..... 16

13 2.4.2 September 12 Technical Conference Feedback..... 17

14 2.4.3 Draft Report Feedback..... 21

15 2.4.4 Public Consultation Process..... 27

16 3.0 PLANNING ENVIRONMENT..... 31

17 3.1 NS Power System Overview..... 31

18 3.2 Air Emissions Legislation and Regulation ..... 32

19 3.3 Renewable Electricity Standards ..... 33

20 3.4 The Maritime Link..... 34

21 3.5 Demand Side Management..... 35

22 3.6 Wind Energy ..... 36

23 3.6.1 NRIS vs. ERIIS Interconnected Wind Generation Resources ..... 38

24 3.6.2 Medium and High Wind ELCC Assumptions ..... 39

25 3.6.3 Wind Integration Costs ..... 39

26 4.0 ASSUMPTIONS & ANALYSIS PLAN DEVELOPMENT..... 41

27 4.1 Introduction..... 41

28 4.2 Assumptions & Analysis Plan ..... 42

29 4.3 Candidate Resource Plans..... 44

30 4.4 Sensitivity Analysis ..... 47

## 2014 IRP Final Report

---

1	4.5	Plan Evaluation .....	47
2	5.0	MODELING RESULTS & PREFERRED RESOURCE PLAN SELECTION .....	52
3	5.1	Introduction.....	52
4	5.2	DSM.....	55
5	5.3	Thermal Fleet.....	56
6	5.4	Renewables .....	57
7	5.5	Sensitivities and Worlds .....	58
8	5.6	Evaluation of Alternative CRPs.....	59
9	5.7	Preferred Plan.....	64
10	6.0	ACTION PLAN.....	66
11	6.1	Action Plan Introduction.....	66
12	6.2	2014 IRP Action Items.....	66
13	6.2.1	Demand Side Management.....	66
14	6.2.2	Renewable Resources .....	67
15	6.2.3	Regional Opportunities .....	69
16	6.2.4	Existing Thermal Resources .....	70
17	6.2.5	Transmission and System Studies.....	72
18	6.2.6	Ongoing Analysis of Value of Capacity Contribution towards Resource	
19		Adequacy Requirements .....	74
20	6.2.7	Planning Reserve Margin.....	75
21	6.2.8	Regulatory.....	75
22	6.2.9	IRP Planning and Modeling Process Improvement.....	76
23	6.3	Strategic Resource Plan Decision Paths .....	77
24	6.4	Risk and Opportunity Analysis.....	77
25	6.4.1	Retirements .....	78
26	6.4.2	DSM.....	78
27	6.4.3	Environmental regulations .....	79
28	6.4.4	Flu Gas Desulphurization .....	79
29	6.4.5	Resource Incompatibility and Unintended Competition.....	80
30	6.4.6	Firm Capacity and ERIS Wind Generation .....	80

1 7.0 GLOSSARY OF TERMS ..... 83

2

3

**LIST OF APPENDICES**

4

5 Appendix A – Terms of Reference

6 Appendix B – Final IRP Assumptions

7 Appendix C – Wind Capacity Value Assumptions

8 Appendix D – Variable Generation Integration Costs Assumptions

9 Appendix E – NS Power Memo: Analysis Plan: March 14, 2014

10 Appendix F – NS Power Memo: Response to Stakeholder Input: April 11, 2014

11 Appendix G – NS Power Responses to Stakeholder Assumptions Comments

12 Appendix H – NS Power Memo: Status Update: June 5, 2014

13 Appendix I – Technical Conference Material: June 25, 2014

14 Appendix J – NS Power Memo: Status Update: July 30, 2014

15 Appendix K – Technical Conference Material: September 12, 2014

16 Appendix L – Detailed CRP Results

17 Appendix M – Firm Capacity Contribution from ERIS Wind

18 Appendix N – Stakeholder Comments

19 Appendix O – PJM Renewable Integration Study

20 Appendix P – MISO Wind Capacity Credit Planning Year 2014-2015

21 Appendix Q – Synapse 2013 Technical Training – Session 2 Best and Worst Practices in IRP  
22 and CPCN

23 | [Appendix R – Synapse and Facilitator Comments on the 2014 IRP](#)

1 **1.0 EXECUTIVE SUMMARY**

2  
3 The 2014 Integrated Resource Plan (IRP) process represents a continuation of Nova  
4 Scotia Power's (NS Power, the Company) previous 2007 and 2009 IRP work. The  
5 process has built on learnings and actions from the previous IRPs to further shape the  
6 future of the Nova Scotia electrical system in a collaborative, consultative and planned  
7 manner. The IRP Terms of Reference (TOR) highlight this objective:

8  
9 To develop a long-term Preferred Resource Plan that establishes the  
10 direction for NS Power to meet customer demand and energy  
11 requirements, and environmental obligations in a cost-effective, safe and  
12 reliable manner across a reasonable range of foreseeable futures; and to  
13 develop an Action Plan describing the major tasks required to implement a  
14 no regrets strategy that aligns with the Preferred Resource Plan during the  
15 first five years of the planning horizon.  
16

17 Since the initiation of the 2014 IRP through the Nova Scotia Utility and Review Board's  
18 (NSUARB, UARB, the Board) letter of December 18, 2013, the Company has worked in  
19 collaboration with Synapse Energy Economics, Multeese Consulting, and The Liberty  
20 Consulting Group (the UARB's Consultants), UARB Staff, and in consultation with  
21 stakeholders. The process was similar to previous IRPs in that a Terms of Reference was  
22 jointly developed and submitted to stakeholders, assumptions were submitted for  
23 comment and an Analysis Plan was sent out for consideration. This collaborative and  
24 consultative process allowed NS Power to use its long term and detailed modeling tools  
25 (Strategist and Plexos) to consider a broad range of potential Candidate Resource Plans  
26 (CRPs) with a focus on four key variables:

- 27  
28
- Plant retirement dates
  - Level of Demand Side Management
  - Level of Renewable Generation
  - Potential for a large PPA
- 29  
30  
31  
32

1 These variables were considered under a Reference World that assumed base load,  
2 current and currently proposed environmental regulations, and energy generated at  
3 Muskrat Falls and delivered to NS Power through the Maritime Link including economic  
4 market purchase opportunities. Worlds where load was flat or growing, or where DSM  
5 did not achieve its potential, were also contemplated.

6  
7 NS Power then tested the sensitivity of the plans to potential changes in market dynamics  
8 including the following:

- 9
- 10 • More stringent air emissions regulations
  - 11 • No further reductions in air emissions regulations
  - 12 • High natural gas, high import power pricing
  - 13 • Low natural gas, low import power price
  - 14 • No Demand Response Programs
  - 15 • Low international price for high sulphur coal
  - 16 • High international price for high sulphur coal
  - 17 • Low cost, high output wind

18  
19 A number of key conclusions can be derived from the data and ensuing analysis  
20 performed by the Company and the feedback garnered from both collaboration with  
21 UARB Staff and consultants and consultation with the stakeholder group:

- 22
- 23 • Investment in renewables and DSM has allowed NS Power to meet its current  
24 environmental obligations and well-positioned the Company to meet pending  
25 environmental requirements.
  - 26  
27 • There is now a near-term window where limited incremental capital spending is  
28 required. This window provides an opportunity to ensure we optimize our near-  
29 term demand and supply-side resources in order to minimize near-term rate

1 pressures without compromising longer term environmental and economic  
2 objectives.

- 3  
4 • An Action Plan focused on developing the optimal balance between near-term  
5 electricity service affordability and ensuring the long-term benefits of DSM and  
6 capital spending are maintained is required. This includes:

- 7  
8 • determining the optimal near-term DSM spending profile;  
9  
10 • assessing the appropriate near and medium term sustaining capital spend  
11 on NS Power generation assets;  
12  
13 • exploring opportunities for enhanced regional integration and cooperation;  
14  
15 • examining additional opportunities to enhance renewable energy  
16 integration and performance;  
17  
18 • calculating the avoided cost of DSM and reporting to stakeholders and  
19 ENSC;  
20  
21 • studying the potential cost and benefit of a flue gas desulphurization unit  
22 at Lingan; and,  
23  
24 • refurbishing the Mersey Hydro System and studying the cost and benefit  
25 of increasing the capacity of that system.  
26

27 The IRP has confirmed that with DSM programing within the range tested, adequate  
28 demand and supply resources are available to NS Power to economically meet its  
29 planning constraints to 2020, without significant capacity additions. Capacity additions  
30 are required across a number of CRPs to meet either Renewable Electricity Standard

1 (RES) requirements or system requirements over the planning period, specifically in the  
2 2030s, for the most economic plans (please note that there will be additional IRPs before  
3 decision points are reached for the 2030s). The current IRP process has served to identify  
4 a number of resource plans which provide comparable costs and benefits to customers  
5 over the long term, but differ significantly in the near term with respect to upward  
6 pressure on power rates.

7  
8 Nova Scotia Power believes that reducing rate pressure in the near term is in the interest  
9 of our customers. In parallel to the technical IRP, Nova Scotia Power has conducted –  
10 and continues to conduct – direct consultation with residential, business, and institutional  
11 customers, as well as elected officials. More than 300 customers have attended NS  
12 Power’s consultation sessions as of the writing of this report. The overwhelming  
13 feedback from customers has been that price is their top priority on electricity: customers  
14 want power rates that are affordable, predictable and stable.

15  
16 Evaluating on a five-year net present value (NPV) basis, the IRP has shown that the near-  
17 term spending level for demand side management is the primary driver of increased  
18 customer costs among the most economic plans. Some IRP participants object to  
19 evaluating on a five-year NPV basis, but NS Power maintains that such evaluation is  
20 essential to assessing near-term rate impacts on customers, and thus is critical to the  
21 planning process. NS Power’s position is further supported by the Terms of Reference,  
22 which recommend “a no regrets strategy that aligns with the Preferred Resource Plan  
23 during the first five years of the planning horizon.”

24  
25 NS Power acknowledges that some parties would prefer that this report include a choice  
26 of a specific Preferred Resource Plan and accompanying level of notional DSM spending  
27 for planning purposes. ~~However, pre-determining a level of DSM, even if only for~~  
28 ~~planning purposes, would limit the ability of Nova Scotia Power, Efficiency Nova Scotia,~~  
29 ~~and ultimately the UARB to finalize an operational level of cost-effective, affordable~~  
30 ~~DSM to be procured by the utility from the DSM provider, in accordance with the~~



1 ~~Electricity Efficiency and Conservation Restructuring (2014) Act. In the interest of~~  
2 ~~customers, the process established by the Act must take precedence.~~

3  
4 ~~The~~Given the results of the IRP process (primarily the lack of a requirement for any  
5 ~~material near-term capital investment), that DSM is the primary variable between the~~  
6 ~~most attractive resource plans and the fact that DSM was not subject to any meaningful~~  
7 ~~review during the IRP, NS Power believes that choosing one Preferred Resource Plan at~~  
8 ~~this time could actually provide a disservice – especially given the pending DSM review~~  
9 ~~process. Furthermore, it is important to note that choosing one Preferred Resource Plan~~  
10 ~~will not change any of the analysis conducted pursuant to the IRP process nor will it add~~  
11 ~~to the information available to participants in the IRP process to inform future~~  
12 ~~discussions. However, pre-determining a level of DSM, even if only for planning~~  
13 ~~purposes, could inappropriately influence the legislated process to finalize an operational~~  
14 ~~level of cost-effective, affordable DSM to be procured by the utility from the DSM~~  
15 ~~provider in accordance with the Electricity Efficiency and Conservation Restructuring~~  
16 ~~(2014) Act.~~

17  
18 ~~After taking into consideration Intervenor submissions on the Draft Report, the Company~~  
19 ~~maintains its conclusion that the~~ results of this Integrated Resource Plan have  
20 demonstrated that there is a common, no regrets path forward for the Action Plan period  
21 and several years thereafter. ~~There are divergent views on key issues such as DSM, rate~~  
22 ~~effects, selection of a Preferred Resource Plan, sustaining capital and how the results for~~  
23 ~~the IRP will be used to continuously inform the system planning process. However, the~~  
24 ~~information that has emerged from the IRP has created the platform necessary for~~  
25 ~~continued dialogue and engagement in the regulatory processes that will effectively, in~~  
26 ~~conjunction with the Action Plan, extend the planning exercise until the next IRP. In~~  
27 ~~fact, though there are areas where consensus has not been reached in the feedback on the~~  
28 ~~Draft Report, Synapse recognizes different conclusions can be drawn from the~~  
29 ~~information, but that there has been significant effort to adequately inform the IRP~~

1 process.<sup>1</sup> NS Power agrees and would highlight that consensus on areas where more  
2 work is needed form the backbone of the Action Plan path forward. This path requires  
3 minimal incremental capital spending for new capacity, while maximizing the lifespan of  
4 existing generation assets and selecting ~~an optimal~~ a preferred level of DSM. ~~While the~~  
5  
6 The detailed Action Plan will resolve ~~some~~ key areas requiring additional study, that  
7 reflect the feedback the Company has received on the Draft Report. A detailed review  
8 and response to this feedback is included in Section 2.4.3 of this report. This  
9 collaborative and consultative IRP process has provided clear direction for the future of  
10 the power system that will benefit Nova Scotia Power customers.

---

<sup>1</sup> Please refer to Appendix R – Synapse and Facilitator Comments on the 2014 IRP.

1 **2.0 INTRODUCTION**

2  
3 An Integrated Resource Plan (IRP) is a comprehensive and public utility planning  
4 exercise that integrates supply and demand-side options to develop a long-term resource  
5 plan for the utility. NS Power filed an Integrated Resource Plan in 2007 and an  
6 Integrated Resource Plan Update in 2009 with the Nova Scotia Utility and Review Board.  
7 In its letter of December 18, 2013 the Board directed NS Power to undertake  
8 development of the full-scale analysis and preparation of a 2014 Integrated Resource  
9 Plan.

10  
11 The 2014 IRP Terms of Reference, as approved by the Board, contains the following  
12 objective:

13  
14 To develop a long-term Preferred Resource Plan that establishes the  
15 direction for NS Power to meet customer demand and energy  
16 requirements, and environmental obligations in a cost-effective, safe and  
17 reliable manner across a reasonable range of foreseeable futures; and to  
18 develop an Action Plan describing the major tasks required to implement a  
19 no regrets strategy that aligns with the Preferred Resource Plan during the  
20 first five years of the planning horizon.<sup>2</sup>  
21

22 The policy judgments and decisions concerning the IRP are made by NS Power in light  
23 of its obligations to its customers and regulator. The resultant Action Plan is a road-map  
24 to guide the utility's strategy for meeting its resource needs over the planning horizon. It  
25 is directional, not prescriptive, in nature, and is meant to provide the utility with  
26 sufficient flexibility to effectively accommodate a range of future uncertainties.  
27

28 This IRP fulfills the Company's obligation to develop a long-term resource plan that  
29 establishes the direction for NS Power which considers customer demand and energy  
30 requirements as well as environmental obligations, cost-effectiveness, safety and  
31 reliability. NS Power has applied the IRP process described in Section 4 of this report in

---

<sup>2</sup> Nova Scotia Power Integrated Resource Plan – 2014 Terms of Reference, Appendix A, page 1.

1 collaboration with UARB staff and its consultants, and in consultation with customer  
2 representatives and interested parties.

3  
4 This chapter outlines the primary steps of the IRP process, summarizes advancements in  
5 the Company's Integrated Resource Planning approach, and provides an overview of the  
6 public process.

7  
8 **2.1 2014 Integrated Resource Plan Process**

9  
10 The primary steps of the Integrated Resource Planning process, and where they are  
11 addressed in this report, are outlined below:

- 12
- 13 • Develop the Terms of Reference and timeline for the IRP – Section 4.1
  - 14
  - 15 • Establish the criteria for evaluation of various plans and selection of the Preferred  
16 Resource Plan(s) – Section 4.2, 4.3, 4.5
  - 17
  - 18 • Develop input assumptions reflecting projections of the most likely values for  
19 variables representing the planning environment and resource options – Section  
20 4.2
  - 21
  - 22 • Evaluate potential resource plans using screening methods, modeling, and  
23 sensitivity analysis – Section 5
  - 24
  - 25 • Select the Preferred Resource Plan based on analysis results – Section 5.7
  - 26
  - 27 • Develop an Action Plan describing major tasks required to implement a no-regrets  
28 strategy that aligns with the Preferred Resource Plan during the first five years of  
29 the planning horizon – Section 6
  - 30

- 1           •       Engage with Stakeholders throughout the IRP process – Section 2.4

2  
3           Section 4 of the TOR requires the IRP report to address 11 specific areas. Those 11  
4           areas, and the section where NS Power addresses them in this document, are as follows:

- 5  
6           1.       Background/Process Overview – Sections 2 and 4  
7           2.       Stakeholder engagement process – Section 2.4  
8           3.       Criteria for evaluation of the various plans – Section 4  
9           4.       Load forecast of future supply requirements – Appendix B (Final Assumptions),  
10           slides 77-94  
11          5.       Sets of alternative supply-side and DSM alternatives to meet future system  
12           requirements – Appendix B (Final Assumptions), slides 35-38 and slides 94-111,  
13           respectively  
14          6.       Screening analysis used to determine which alternatives were evaluated – Section  
15           4  
16          7.       Evaluation of alternative plans in order to determine the least cost plans and rates  
17           impact – Section 5  
18          8.       Sensitivity analysis on the least cost plans and other selected plans to determine  
19           the robustness of the plans to variations in input assumptions – Section 5  
20          9.       Preferred Resource Plan – Section 5  
21          10.      Avoided cost of DSM methodology method utilized and results – Section 6  
22          11.      Action Plan. Actions required over the next 5 years to meet load projections and  
23           other regulatory and environmental requirements through implementation of a no  
24           regrets strategy that follows the Preferred Resource Plan – Section 6

25  
26   **2.2    Advancements in the IRP Approach**

27  
28           This IRP builds on NS Power’s prior resource planning efforts and reflects continued  
29           advancements in resource plan modeling and methodology. These advancements are  
30           described in Sections 2.2.1 – 2.2.3.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**2.2.1 Candidate Resource Plan (CRP) Approach**

In previous IRPs, the resource plans were produced by the output of Strategist. The Base World assumptions were run through the model and from the numerous output resource plans developed, candidate plans to be considered for the Preferred Plan were selected. For the 2014 IRP, UARB staff and consultants recommended the Candidate Resource Plan approach and the Company agreed to employ this methodology. Advantages of the Candidate Resource Plan approach (a full description of the CRP approach is included in Section 4.2 of this report) are the ability to test a wide range of possible outcomes while minimizing the required computing time. While providing advantages within the relatively short timeframe allotted for the execution of the IRP, one of the challenges with the Candidate Resource Plan approach was the development of a fully optimized resource plan. Major components of resource plans, such as level of DSM, steam unit retirements and wind generation additions, are pre-determined rather than optimized,<sup>3</sup> so the optimal path forward may prove to be a combination of the most favorable aspects of the top performing Candidate Resource Plans. While it is possible to select the best of the Candidate Resource Plans, it is clear that many of the plans could be further optimized.

A table describing the CRPs can be found in Section 4.3, page 39 of this report.

**2.2.2 Evaluation with Plexos**

Operational viability of a select set of Candidate Resource Plans was tested in chronological hourly dispatch optimization software examining CRP performance within unit commitment, system security and other system dispatch constraints.

---

<sup>3</sup> While Strategist can optimize various levels of DSM year to year, due to the problem size, this process is time consuming and it could not have been completed in the IRP time frame.

1 NS Power described the basis for using Plexos in its July 30 Memo to stakeholders:

2  
3 The Company proposes to use Plexos to examine certain CRPs (i.e. high  
4 wind, high DSM, Scenario “C” emissions) to evaluate key system  
5 operational attributes that Strategist does not evaluate, such as dispatch  
6 within generating unit commitment constraints, transmission system  
7 constraints, dynamic reactive reserve requirements, wind generation  
8 curtailment, and other chronological system constraints. The analysis may  
9 show that the system needs reinforcement or that, although Strategist has  
10 indicated that a given CRP meets the system’s annual capacity, generation  
11 and emissions needs, the CRP does not satisfy the system’s hourly  
12 operational needs. NS Power will use its engineering judgment, in  
13 collaboration with Synapse, to determine which CRPs require Plexos  
14 analysis. NS Power will document its rationale for choosing to apply  
15 Plexos to specific CRPs. It will also identify any CRP that it excludes  
16 from further consideration based upon the Plexos assessment and the  
17 reasons for that exclusion.<sup>4</sup>  
18

19 Chronological dispatch analysis offers several indicators of system stress under certain  
20 CRPs’ system configurations and these are wind energy curtailment, uneconomic exports,  
21 system constraint violations, steam unit start-stops, heat rate impact, barriers to  
22 purchasing otherwise economic Maritime Link surplus energy, etc. The use of Plexos in  
23 conjunction with Strategist is an adaptation of the NS Power IRP process reflecting the  
24 complexity of the power system as it transitions away from base loaded coal generation.  
25

### 26 **2.2.3 Sustaining Capital Investments**

27  
28 Sustaining capital investments for existing and new thermal units were included in the  
29 cost comparison among Candidate Resource Plans. Sustaining ~~Capital~~capital investments  
30 are investments to maintain NS Power’s generation fleet. This is the first IRP where  
31 sustaining capital was added to the modeling exercise due to the variety of retirement  
32 options. Sustaining capital costs for the Minimum (early,~~base~~), Medium and  
33 ~~max~~Maximum coal use retirement assumptions are calculated outside of Strategist and  
34 added as an input to the model. Steam unit retirements have not been a feature of

---

<sup>4</sup> Appendix J – NS Power July 30, 2014 memo to stakeholders.

1 previous NS Power IRPs. NS Power modeled a 60-year life for steam resources, and this  
2 assumption was modified following stakeholder consultation to reflect two additional  
3 (shorter life) steam resource retirement strategies. To allow for the side-by-side  
4 comparison of CRPs with differing retirement strategies in the planning period, it became  
5 necessary to include sustaining capital investments for these assets.

### 7 **2.3 Role of Board Staff and Consultants**

8  
9 NS Power's 2014 Integrated Resource Plan has been developed as a joint effort between  
10 the Company and Board staff and consultants. This collaboration has included:  
11 establishing the Terms of Reference and key evaluation criteria; identifying key input  
12 assumptions; designing the analysis framework; screening, selecting and assessing  
13 resource plans and analyzing model results. In addition, Board consultants provided  
14 comments on draft versions of this report.

15  
16 The knowledge brought to this project by Board staff and consultants, Synapse Energy  
17 Economics, Inc., Multeese Consulting Inc., and The Liberty Consulting Group, along  
18 with NS Power technical and analytical expertise, has produced a comprehensive IRP.  
19 The key outcomes confirm the direction indicated by the 2009 IRP Update and have  
20 resulted in an Action Plan which the Company believes will enable it to meet future  
21 customer needs as well as environmental, safety, and reliability obligations.

### 23 **2.4 Stakeholder Consultation & Public Process**

#### 25 **2.4.1 Stakeholder Consultation**

26  
27 Stakeholder input is an integral part of the IRP process. In accordance with the 2014 IRP  
28 Terms of Reference, NS Power consulted with stakeholders throughout the planning  
29 process.



1 Technical Conferences were conducted with regulatory stakeholders on March 7, June  
2 25, and September 12, 2014. Stakeholder update memos were also distributed on April  
3 11, June 5 and July 30. Comments were accepted and considered by the Company from  
4 stakeholders throughout the 2014 IRP process, including comments on the Company's  
5 analysis results presented on September 12. Appendix N contains all comments and  
6 written feedback received by the Company from stakeholders throughout the 2014 IRP  
7 process. NS Power has responded to feedback it received from stakeholders (Appendices  
8 F, G and H) and offers the following for consideration based on the September 12  
9 feedback.

#### 11 2.4.2 September 12 Technical Conference Feedback

12  
13 Generally speaking, the Company has identified 4 main areas that are of concern to the  
14 stakeholder group. These are listed below followed by NS Power's response to each.

- 16 • The Role of a Preferred Resource Plan
- 17 • The Role of the Action Plan
- 18 • DSM
- 19 • IRP Timelines and Content

#### 21 The Role of a Preferred Resource Plan

22  
23 Often in advance of initiation of an IRP, the need for specific capacity additions or  
24 potential changes to the planning environment are identified in the near-term and these  
25 additions or changes are the basis for initiating the planning exercise. This was the case  
26 in 2007 and 2009 for NS Power's previous IRPs. Changes to emissions and renewable  
27 regulations required the Company and stakeholders to examine what was the most cost-  
28 effective means to manage existing capacity as new capacity came online. ~~The 2014 IRP,~~  
29 ~~however, is quite different.~~The 2014 IRP is quite different; loss of industrial load,  
30 certainty around emissions targets and the addition of the Maritime Link are key

1 | considerations for the future resource mix. Through the course of this process, the  
2 | analysis has shown that with the addition of the Maritime Link, maximized life of current  
3 | assets and a level of DSM to be determined by a subsequent regulatory process, the  
4 | Company can meet its near-term<sup>5</sup> capacity and energy needs.  
5 |

6 | Several plans have emerged that produce similar, ~~“no regrets”~~ paths for the first five  
7 | years of the Action Plan. In CRPs 1, 2 and 5, there is minimal incremental capital  
8 | investment required to meet emissions and renewable energy requirements out to 2020.  
9 | The main variable between these plans is the level of DSM investment required. There  
10 | are other plans that are less economic over various time horizons that the Company can  
11 | implement if there are significant changes to load or environmental regulations.  
12 |

13 | NS Power has planning flexibility over the next 5 years because the least cost alternatives  
14 | emerging from the IRP do not call for new capacity additions in that window. The  
15 | Company proposes to take advantage of this flexibility by implementing the items  
16 | identified in the Action Plan.  
17 |

### 18 | **The Role of the Action Plan**

19 |  
20 | NS Power has developed a robust Action Plan to address its findings from the IRP  
21 | analysis. The Company proposes to examine further elements raised by stakeholders as  
22 | items for further study and areas where the Company has firm deliverables. This type of  
23 | detailed Action Plan, with input from the Board’s consultants and in consultation with  
24 | stakeholders, requires the Company to perform the work per the established timelines.  
25 | The resulting required information will be available to inform the next long-term  
26 | planning exercise.  
27 |

28 | The Action Plan contains a number of items that emerged from the IRP and are critical  
29 | elements for planning the future of the power system. The Action Plan will significantly

---

<sup>5</sup> “near-term” is out to 2020.

1 bolster the content of the 10 Year System Outlook Report, filed annually. The 10 Year  
2 System Outlook is a report to the UARB which describes NS Power's system for the next  
3 10 years, from a system operations perspective. The report will inform stakeholders of  
4 key items raised in the IRP, for example: plant retirement schedulesforecasts, regional  
5 integration and the requirement for flexible generation assets. There are also significant  
6 standalone studies that will be completed as part of the Action Plan raised by the  
7 stakeholder group, including: an Energy Resource Interconnection Resource/Network  
8 Energy Resource Interconnection Request (ERIS/NRIS) capacity value study, a study to  
9 determine the viability and potential economic benefit of adding a flue gas desulphurizer  
10 and a detailed examination of the Company's sustaining capital spend for its generation  
11 fleet.

12  
13 The Action Plan provides the means to conduct further analyses of areas that were not  
14 fully examined during the IRP or emerged from the analysis of this IRP.

15  
16 **DSM**

17  
18 Stakeholders have varying views on DSM; some advocate for higher or lower DSM  
19 levels, while recognizing that there should be a separate process to determine the level of  
20 DSM that will be implemented. Feedback from the Industrial Group, the Consumer  
21 Advocate and the Small Business Advocate, representatives for the vast majority of NS  
22 Power's customers, acknowledges that DSM has its own regulatory process outside of the  
23 IRP. Efficiency NS (ENSC) also acknowledges this in their submission following the  
24 September 12 Technical Conference. This is aligned with NS Power's position in its  
25 Action Plan. The Company proposes to engage ENSC to bring a filing to the UARB for  
26 approval. This aligns with what is called for under the provisions of the recently  
27 amended Public Utilities Act for electricity efficiency and conservation activities.

28  
29 Given the direction provided within the newamended Public Utilities Act, NS Power  
30 believes that the IRP is not the appropriate forum to derive an optimal level of DSM.

1 | Instead ~~NS Power believes~~ the newamended Act requires ~~the formal process to approve~~  
2 | ~~the level of DSM to be~~ a separate regulatory proceeding to determine the cost-effective,  
3 | affordable level of DSM.

4 |  
5 | The IRP process has informed NS Power and stakeholders that different levels of DSM  
6 | investment will produce different cost profiles over time. In ~~conjunction~~consultation  
7 | with stakeholders, NS Power will ~~also~~ produce an avoided cost analysis of DSM as part  
8 | of the Action Plan. The Company can also use the IRP modeling tools to determine how  
9 | best to balance cost effectiveness and affordability ~~during the establishment~~as part of  
10 | ~~an~~the application with ENSC to be made to the UARB to approve the 2016-2018 DSM  
11 | investment profile.

12 |  
13 | As part of its Action Plan, the Company will produce the additional modeling requested  
14 | by the Industrial Group:

15 |  
16 |       The Industrial Group requests that NSPI model an optimum DSM  
17 | spending profile on a variable basis, having regard to any operational  
18 | constraints (on the part of NSPI and ENS). It is understood that NSPI and  
19 | ENS will be negotiating an agreement for the delivery of efficiency  
20 | programs on three year terms so the ultimate level of DSM will be  
21 | determined in that process and approved by the Board; nonetheless, for  
22 | planning purposes, it would be helpful to understand the implications of an  
23 | optimum variable DSM spend...

24 |  
25 |       The Industrial Group requests that NSPI run a sensitivity of both higher  
26 | and lower costs of DSM per MWh and also higher and lower achievable  
27 | energy and demand savings for the same DSM dollar investment (Base,  
28 | Half Low).

### 30 | **IRP Timelines and Content**

31 |  
32 | The IRP timeline has been challenging. The Company endeavoured to provide  
33 | stakeholders with ~~a~~a meaningful opportunity to comment on the process at critical  
34 | stages. NS Power sees the Action Plan period as an important vehicle for resolving key  
35 | resource matters and to shape the next IRP. ~~The Company does not consider the end of~~

---

1 ~~the analysis phase to be the conclusion of the IRP.~~ There is significant work ahead and  
2 NS Power would like to continue to engage the stakeholder group as part of that process.  
3 Having a robust Action Plan and several low-cost resource plans with similar no-regrets  
4 paths will allow the Company to maintain a broad perspective on near to longer-term  
5 resource options and ensure stakeholders have the opportunity to remain fully engaged in  
6 resource planning matters leading to the next IRP.

7  
8 **2.4.3 Draft Report Feedback**

9  
10 The Terms of Reference provides for stakeholder comment on the Draft Report and  
11 Action Plan prior to the Final Report being submitted to the UARB. The Company  
12 thanks the Board’s consultants and stakeholders for the detailed and valuable feedback it  
13 has received. Appendices N and R include all feedback received on the Draft Report.  
14 This Final Report reflects changes suggested by the stakeholders where appropriate and  
15 additional comments are included below based on common themes that have emerged  
16 from the stakeholder comments. Generally the comments can be organized based on the  
17 following themes:

- 18
- 19 • Responsiveness, IRP timeline, Next Steps
- 20 • Selection of a Preferred Resource Plan and Plan Evaluation
- 21 • DSM
- 22 • Sustaining Capital
- 23 • Maritime Link
- 24 • Wind Capacity Value
- 25 • Affordability and Rate Effects
- 26

27 **Responsiveness, IRP timeline and Next Steps**

28

29 Through the IRP process there has been feedback suggesting that the timeline and level of  
30 engagement was not sufficient to come to a final report and close out the IRP. Customer  
31 representatives, including the Consumer Advocate, Small Business Advocate and

1 Industrial Group, have identified concerns with their ability to participate within the IRP  
2 timelines. The Company recognizes these concerns along with its need to comply with  
3 the UARB-established timeline. The Company has worked with Synapse to create a  
4 detailed Action Plan that commits to engage stakeholders beyond the close of the  
5 modeling and reporting phases of the IRP through the Action Plan Period.

6  
7 The information from the IRP modeling and reporting phases remains useful for the  
8 duration of the planning period and serves to inform future regulatory processes. These  
9 phases of the IRP have been successful at providing the underlying data that will inform  
10 the planning decisions that need to be made over the Action Period. The UARB and  
11 stakeholders can be confident that where required, such as for decisions relating to DSM,  
12 sustaining capital or capacity additions, the information from the IRP will be utilized to  
13 provide value to customers. This is consistent with previous IRPs in that the Integrated  
14 Resource Plan is not an approval of discrete projects or a prescribed path, as expressed in  
15 the TOR:

16  
17 The IRP is a comprehensive and public utility planning exercise that  
18 integrates supply and demand-side options to develop a long-term  
19 Preferred Resource Plan for the utility. The resultant Preferred Resource  
20 Plan is a road-map to guide the utility's strategy for meeting its resource  
21 needs over the planning horizon. It is directional, not prescriptive in  
22 nature. The Preferred Resource Plan does not commit the utility to certain  
23 courses of action or foreclose options determined to be in the interests of  
24 our customers subsequent to completion of the IRP process. Instead, the  
25 Preferred Resource Plan is meant to provide the utility with sufficient  
26 flexibility to effectively accommodate a range of future uncertainties.  
27

28 The Action Plan phase of the IRP begins with the submission of this Final Report and NS  
29 Power commits to ongoing reporting to the UARB and interested parties on its progress  
30 against the Action Plan.

31  
32 **Selection of a Preferred Resource Plan and Plan Evaluation**  
33

1 The stakeholder group has expressed contrasting views regarding both the need to select a  
2 specific resource plan based on a CRP (including a DSM level) and the time horizon that  
3 should be the primary consideration to evaluate plans. Several stakeholders (NS  
4 Department of Energy, SBA and Industrial Group) have asked NS Power to be especially  
5 mindful of potential rate impacts over the next 5 years provided that long term  
6 affordability is not compromised. Others (PHP, Synapse, ENSC) believe that plan  
7 evaluation should primarily consider the planning and study period costs even if this  
8 could cause rate pressures in the short term. However, all parties recognize that there is a  
9 convergence of the most economic plans over the planning horizon. Several plans fall  
10 within 5 percent of the plan with the lowest planning period NPV. NS Power has focused  
11 on short and medium term affordability as a means to distinguish between plans in the  
12 interest of customers, knowing that the next IRP will better inform the longer term  
13 capacity addition decisions which separate the plans. The early-year convergence of the  
14 mix of plans that are most economic over the short, medium and long terms respectively  
15 (CRP 1, 2-17 and 5) also diminishes the need to pick from among plans that are not fully  
16 optimized. Rather, the Company selected the direction (wind levels, plant retirement  
17 dates, etc.) that are common to the most economic plans and has used that direction as the  
18 basis for its Action Plan.

19  
20 The TOR does not require the Company to choose a Preferred Resource Plan based on all  
21 attributes of a single CRP. By combining common attributes from CRPs that perform the  
22 best over a variety of timeframes, the Company is in fact moving closer to an optimal  
23 system plan. Synapse, by submitting a new and previously undiscussed CRP, also  
24 recognizes that the CRP process has not produced a fully optimized plan and that there is  
25 opportunity to further optimize elements (i.e. DSM, planning reserve, sustaining capital)  
26 of the CRPs on a go-forward basis to ensure customers have the most economic and  
27 affordable system. Additional support for this position stems from requests from the  
28 Industrial Group and Government for additional analysis around DSM spend levels.

29  
30 DSM

1  
2 Both the CA and the Department of Energy highlight in their submissions that there has  
3 been no consensus reached in the IRP on the appropriate level of DSM. This is not  
4 surprising since, at its outset, the IRP did not intend to optimize for DSM. Rather the  
5 CRP process was designed to test the effect of 3 DSM levels; Low, Base and High. The  
6 High, Base and Low assumptions for DSM were developed in collaboration with the  
7 Board’s consultants and vetted by the stakeholder group, as was their incorporation in the  
8 various CRPs during the assumptions and analysis phases of the IRP. At the outset of the  
9 IRP it was communicated that while DSM would be modelled in the IRP, NS Power  
10 anticipated that the optimal level of DSM would result from a separate regulatory process  
11 (please refer to quote at page 35).

12  
13 However, there does seem to be consensus that establishing an optimal DSM level is  
14 critical to the IRP process. The Department of Energy and the Industrial Group have  
15 requested, based on near-term affordability concerns, that additional analysis should be  
16 conducted on the Base and Low DSM values used in the IRP. Synapse, the Ecology  
17 Action Centre and Port Hawkesbury Paper have requested that additional analysis be  
18 conducted on the Base and High levels of DSM, based on concerns for long term NPV. It  
19 bears noting that the cost of DSM programs is not currently recovered from PHP nor does  
20 it participate in DSM programs; however, PHP is on a fixed, marginal cost based rate  
21 until 2019 and incremental DSM is likely to cause marginal costs to decrease or remain  
22 stable. NS Power’s approach accommodates the requests for an optimal level of DSM as  
23 part of the Action Plan and will use the learnings from the new DSM structure to inform  
24 future IRP updates. NS Power has also committed to consulting with interested parties  
25 on the development of the avoided costs of DSM as part of the Action Plan.

26  
27 The optimal level of DSM should be something that can be flexible through time to meet  
28 the needs of the power system. The IRP has supplied the information necessary to  
29 determine the range of resource needs over the short, medium and long term. The  
30 optimization process can be ongoing with appropriate lead time and determined based on



1 the system needs at the time of DSM procurement, much like capacity additions. The  
2 Company intends to engage stakeholders in assessing and proposing the appropriate DSM  
3 level for approval but agrees with the Industrial Group that this should not be part of the  
4 formal negotiations nor should it preclude the Intervenors' right to question the validity  
5 of the DSM supply arrangement.

### 6 **Sustaining Capital**

7  
8  
9 The Company notes the comments of Synapse, the Industrial Group and the Small  
10 Business Advocate regarding sustaining capital. Items in the Action Plan are intended to  
11 give stakeholders enhanced visibility into the Company's asset management plan and the  
12 resulting sustaining capital. This should allow future ACE Plan proceedings, which  
13 propose for approval sustaining capital spend, to be adequately informed.

### 14 **Maritime Link**

15  
16  
17 The Industrial Group has questioned why the IRP did not examine a variety of  
18 sensitivities for the Maritime Link, citing NS Power's Plexos analysis that High DSM  
19 and High wind penetration levels erode the ability of the system to maximize purchases  
20 of economic energy off of the Maritime Link. Contrary to this assertion, this analysis  
21 demonstrated the economics of the Maritime Link rather than calling them into question:  
22 the High DSM, High/Base wind scenarios that were tested for system operability in  
23 Plexos (CRP 6, CRP 8) ranked 13<sup>th</sup> and 11<sup>th</sup> respectively for planning period NPV. In  
24 comparison, the top ranked plans on an NPV basis allowed for more use of economic  
25 energy off of the Maritime Link.

### 26 **Wind Capacity Value**

27  
28  
29 The CA has provided detailed comments on the capacity value of wind that should be  
30 assumed on a go-forward basis. The Company concluded in consultation with Synapse

1 that for the purpose of the IRP analysis 17 percent was used for the capacity value of  
2 NRIS connected wind. NS Power has committed to examining this value as part of the  
3 Action Plan and would welcome further input from the CA as part of this Action Plan  
4 item. NS Power's review of this issue reveals that the industry continues to refine the  
5 tools used to determine the capacity value of wind generation, and annually adjusted  
6 approaches are emerging in some jurisdictions which reflect both the ongoing additions  
7 of installed wind generation and the variability of this resource.

8  
9 **Affordability and Rate Effects**

10  
11 As stated previously, many of the most economic plans share similar directions and are  
12 close in NPV for much of the planning period. NS Power therefore considered rate  
13 effects as a key criterion for CRP evaluation. Additional weight was given to plans that  
14 had the ability to mitigate rate pressure in the near term, as assumptions are usually more  
15 accurate over the near term and uncertainty increases as the planning period lengthens  
16 and the operational aspects of the Maritime Link are optimized. The Department of  
17 Energy, SBA and Industrial Group agree that affordability and rate effects are an  
18 important consideration for the planning period and that NS Power should consider near-  
19 term rate effects, provided it does not sacrifice long term economic value. PHP  
20 recognizes that there is merit to considering near-term rate effects as well. PHP,  
21 however, raises an important point: an IRP is not a rate setting exercise. NS Power  
22 agrees. The goal of the IRP was not to compare and contrast absolute power rates over  
23 the planning period amongst various CRPs. The SBA and Synapse are critical of NS  
24 Power's use of NPVs over various periods (5, 15 and 25 years) and the partial revenue  
25 requirements as a proxy for rate effects and affordability. The Company recognizes, as  
26 does the SBA in its submission, that there are rate treatments that are possible under the  
27 Nova Scotia regulatory framework to potentially mitigate rate pressures, to an extent,  
28 from an operational vs. planning perspective. Therefore, notional rate effect and  
29 affordability concerns are best expressed using the relative comparators used by NS  
30 Power to contrast plans against the lowest partial revenue requirement plan and lowest

1 NPV plans across various time horizons. To do otherwise, by producing an absolute rate  
2 in cents per kWh, is to portend a level of operational rate setting potential that the IRP  
3 planning exercise was never intended to have.

4  
5 The Company has used the analytical tools that are common to all plans in the IRP –  
6 NPV and partial revenue requirements from Strategist – as a proxy to evaluate potential  
7 rate effects and affordability. However, there is a difference between the operational  
8 reality of rate setting and the use of proxy comparators for planning purposes. NS Power  
9 will strive to find operational rate solutions that keep affordability front and centre, but  
10 will allow for transparency and comparability across plans by using the planning exercise  
11 proxies of NPV and partial revenue requirements to represent affordability and rate  
12 effects.

13  
14 **2.4.32.4.4 Public Consultation Process**

15  
16 Nova Scotians have a great deal of interest in electricity issues. The Company  
17 continually engages customers through tools like the NS Power website,  
18 TomorrowsPower.ca, and regional meetings to have a dialogue on the different aspects of  
19 the electrical system. The 2014 Integrated Resource Planning process presented a  
20 significant opportunity for NS Power to engage customers in a dialogue about long term  
21 electricity planning and to discuss the various challenges and opportunities with  
22 customers.

23  
24 **Customer Engagement Sessions**

25  
26 The Company held ~~thirteen~~fifteen customer engagement sessions in regions across Nova  
27 Scotia. Invitations to the events were extended by NS Power to a broad representation of  
28 stakeholders. Stakeholders were encouraged to forward the invites to their own  
29 networks. An electricity primer with information on key aspects of Nova Scotia's

1 electricity system and issues related to the IRP process was shared with participants to  
2 help them prepare.

3  
4 The sessions included an overview by NS Power's Vice President, Generation and  
5 Delivery, of the key IRP issues and how customer input will guide long term plans. For  
6 the purposes of the discussion, the content for the sessions was crafted based on four  
7 themes that align closely with the various aspects of the overall IRP process: cost,  
8 innovation, energy sources and reliability. Each session was broken into four groups  
9 based on the above four topic areas. For each of the topic areas, participants were asked  
10 the following questions:

- 11  
12 1) What are your thoughts on this topic?  
13 2) What outcomes do you care most about?

14  
15 Information boards about the four topics were used to trigger conversations. Facilitators  
16 recorded responses, which were later used towards reports shared with the participants  
17 and posted on our TomorrowsPower.ca website. The Company finished the session with  
18 an open question and answer period.

19  
20 In November, NS Power intends to hold a second round of sessions throughout the  
21 province to report back to the stakeholders on the outcome of the IRP.

22  
23 NS Power met with approximately 300 customers about the IRP through these sessions.  
24 The Company provided an exit survey to each participant to collect their feedback on the  
25 sessions as well as their overall perspective on NS Power. Customers who attended the  
26 engagement sessions provided a positive rating of the session (94 percent). In addition, a  
27 large majority of participants found the sessions to be informative (82 percent) and useful  
28 (87 percent). Overall, a vast majority of the participants found the events to be an  
29 effective platform to share feedback and learn about electricity planning.

1       **Online Engagement and Other Activities**

2  
3       NS Power also provided an online customer engagement platform called  
4       TomorrowsPower.ca. On this website, we encouraged customers to “ask us anything”,  
5       read information on the IRP (based on the four topic areas mentioned above) and answer  
6       poll questions developed on key themes that arose during the deliberative polling  
7       stakeholder sessions. The Company created awareness about the process through some  
8       paid advertising, NS Power’s customer newsletter “Connections” and social media.

9  
10       NS Power provided a dedicated email address for customers to get in touch directly with  
11       the IRP Team, [electricityplanning@tomorrowpower.ca](mailto:electricityplanning@tomorrowpower.ca), and responded to follow-up  
12       phone calls. At various public events, NS Power used a board, and an opportunity for  
13       customers to provide input on their priorities and thoughts for our electricity future.

14  
15       From April 2014 to the present, nearly 300 questions were submitted through  
16       TomorrowsPower.ca for which we have provided answers with the help of NS Power’s  
17       technical experts, with close to 21,000 unique visits to the website during the same  
18       period. This includes collecting brief written comments on the future of electricity.

19  
20       **Conclusions**

21  
22       As stated above, the objective of using a variety of tools was to ensure the process would  
23       be relevant for as many customers as possible. Here are the key insights we heard in  
24       order of priority:

- 25  
26       •       Affordability<sup>6</sup> is a key concern for residential and business customers and the  
27       importance of striking a reasonable balance between cost and moving to a greener  
28       grid.

---

29  
<sup>6</sup> Affordability was defined as having the minimum revenue requirement increase possible over the near term.

## 2014 IRP Final Report

---

- 1           •       In almost all cases, the outcomes identified as most important to customers had  
2                    strong financial and/or environmental considerations.
- 3
- 4           •       Customers would like to see Nova Scotia Power provide more information about  
5                    the business, and education on existing programs that will help them manage  
6                    usage and reduce their costs.
- 7
- 8           •       On the topic of reliability, customers emphasized the importance of improved  
9                    outage and restoration communications as well as continuous investment in  
10                  preventative maintenance.
- 11
- 12          •       On the topic of energy sources, the majority of participants validated NS Power's  
13                    focus on a diversified portfolio, with an emphasis on the best utilization of local  
14                    sources.
- 15
- 16          •       On the topic of innovation, we heard customers' overwhelming desire for more  
17                    awareness on innovation programs that we already offer, such as the heat pump  
18                    program and Time-of-day rates. There was a strong interest in technologies that  
19                    allow customers to see real time information on and control over their electrical  
20                    use.
- 21

22           The Company will be reporting back detailed results to stakeholders both online as well  
23           as through a second round of sessions throughout the province in November. NS Power  
24           will also take the opportunity to inform customers about the technical IRP submission  
25           with the Board.

26

27           NS Power has been encouraged by the positive response and the level of engagement the  
28           process has generated. The Company intends to continue the dialogue with customers  
29           going forward.

1 **3.0 PLANNING ENVIRONMENT**

2  
3 **3.1 NS Power System Overview**

4  
5 NS Power is a vertically integrated electric utility, regulated by the Nova Scotia Utility  
6 and Review Board. The Company serves approximately 501,000 residential,  
7 commercial, industrial and municipal customers across Nova Scotia. In 2013 system  
8 peak load was 2,033 megawatts; net system requirement was 11,193 gigawatt hours.

9  
10 Nova Scotia's generation portfolio is comprised of a mix of fuel types that includes coal,  
11 petroleum coke, diesel and heavy fuel oil, natural gas, biomass, wind and hydro. In  
12 addition, NS Power purchases renewable energy from Independent Power Producers  
13 located in the Province resulting in total firm capacity of 2,341 MW. The table below  
14 summarizes the resource mix of the Company's generation fleet.

15

<b>Generation Type</b>	<b>Capacity (Firm MW)</b>
Coal/Petcoke	1,247
Natural Gas/Heavy Fuel Oil	321
Natural Gas Combined Cycle	147
Diesel Combustion Turbine	194
Hydro	376
NS Power Wind (firm)	5
Independent Power Producers Renewable (firm)	51
<b>Total Existing Firm Capacity</b>	<b>2,341</b>

16

1 **3.2 Air Emissions Legislation and Regulation**

2  
3 Nova Scotia Greenhouse Gas Emission Regulations outline hard caps for 2010 to 2030.<sup>7</sup>  
4 Nova Scotia was the first jurisdiction in North America to place a “hard cap” on  
5 greenhouse gas (GHG) emissions from the electricity sector.  
6

7 In September 2012, the Federal Government released its regulations for coal-fired  
8 electricity generators to come into force in 2015. The regulations would require coal-  
9 fired units to meet a GHG emissions standard of 420 t CO<sub>2</sub>/GWh or to be retired at the  
10 end of their useful life, approximately 50 years from commissioning.<sup>8</sup> In September  
11 2012, the Federal and Provincial governments released a draft equivalency agreement.<sup>9</sup>  
12 In June 2014, Environment Canada posted the draft Order authorizing the GHG  
13 Equivalency in the federal Gazette Part 1. Once finalized, likely in early 2015, the  
14 agreement will ensure provincial regulations will apply in Nova Scotia and electricity  
15 customers will receive the full value of the coal-fired generating facilities.  
16

17 Nova Scotia Air Quality Regulations outline hard targets for SO<sub>2</sub>, NO<sub>x</sub>, and Hg until  
18 2020. In June 2013, Nova Scotia Environment released a discussion paper<sup>10</sup> outlining  
19 emission limits for SO<sub>2</sub>, NO<sub>x</sub>, and Hg until 2030. The general intent for emissions  
20 reductions targets described in the discussion paper is consistent with the Department’s  
21 goal of long term reductions.  
22

---

<sup>7</sup> An Agreement on the Equivalency of Federal and Nova Scotia Regulations for the Control of Greenhouse Gas Emissions from Electricity Producers in Nova Scotia (September 2012).

<sup>8</sup> Canadian Environmental Protection Act, 1999, Reduction of Carbon Dioxide Emissions from Coal-fired Generation of Electricity Regulations.

<sup>9</sup> An Agreement on the Equivalency of Federal and Nova Scotia Regulations for the Control of Greenhouse Gas Emissions from Electricity Producers in Nova Scotia (September 2012).

<sup>10</sup> Amendments to Greenhouse Gas & Air Quality Emissions Regulations Discussion Paper (NSE, June 2013).



1 **3.3 Renewable Electricity Standards**

2  
3 Nova Scotia Renewable Electricity Regulations outline the Renewable Electricity  
4 Standards. The Renewable Electricity Standards are summarized below:

- 5
- 6 • As of 2014, at least 10 percent of net sales must be generated by renewable  
7 electricity, of which 5 percent can be owned by NS Power (not including NS  
8 Power owned renewables built prior to 2001).
  
  - 9  
10 • As of 2015, at least 25 percent of net sales must be generated by renewable  
11 electricity, of which at least 5 percent plus an additional 300 GWh must be  
12 supplied by IPPs. The additional generation may be supplied by the feed-in-tariff  
13 program, facilities owned by NS Power, or other sources of renewables. NS  
14 Power can only supply 150 GWh or less from co-firing biomass.
  
  - 15  
16 • As of 2020, at least 40 percent of net sales must be generated by renewable  
17 electricity, of which at least 5 percent plus an additional 300 GWh must be  
18 supplied by IPPs. The additional generation may be supplied by the feed-in-tariff  
19 program, distribution connected generators, up to 150 GWh of biomass co-firing,  
20 other NS Power-owned facilities, or other sources of renewables, as well as 20  
21 percent of the generation produced at the Muskrat Falls facility currently under  
22 construction.
  
  - 23  
24 • In addition, there is also a requirement to procure or generate 260 GWh of firm  
25 renewable electricity in 2013 and 350 GWh of firm renewables in 2014 and  
26 subsequent years. The regulatory definition of firm indicates this generation must  
27 be from sources commissioned after December 31, 2001, of which the Port  
28 Hawkesbury Biomass facility would apply.
  
  - 29

1 **3.4 The Maritime Link**

2  
3 On July 22, 2013, the UARB concluded that the Maritime Link was the lowest long term  
4 cost alternative for electricity supply for Nova Scotia in accordance with section 5.1 of  
5 the Maritime Link Regulations. However, the UARB concluded that this was only the  
6 case if customers had access to market-priced energy.<sup>11</sup> Subsequently, NSP Maritime  
7 Link (NSPML) negotiated an Energy Access Agreement with Nalcor to ensure that Nova  
8 Scotians have access to market priced energy flowing through the province from the  
9 Maritime Link. NSPML then submitted a Compliance Filing to the UARB and final  
10 approval was given to the Maritime Link on November 29, 2013.

11  
12 The Maritime Link is a 500 MW high voltage direct current (HVDC) cable that will bring  
13 energy from the Muskrat Falls Hydro project in Newfoundland and Labrador through  
14 Nova Scotia. There are several different components to the energy available from the  
15 Link. First is the Nova Scotia Block of approximately 0.9 TWh annually (153MW firm  
16 capacity 16 hours/day), which is essentially 20 percent of the Muskrat Falls output  
17 adjusted for line losses over a 35 year period. NS Power also receives a Supplemental  
18 Energy Block of approximately 0.24 TWh annually for the first five years of operation  
19 delivered in the overnight hours of November through March. Nova Scotians will also  
20 have access to an average of 1.2 TWh of market priced energy annually under this  
21 agreement and Nalcor has agreed to bid its forecast of up to 1.8 TWh of energy annually,  
22 meaning that Nova Scotians will have the opportunity to bid on the full forecast.

23  
24 When combined with the Nova Scotia Block, the Maritime Link has the potential to  
25 provide 2.6 TWh of Nova Scotia's annual energy requirement for beyond the length of  
26 the IRP planning period. The Link is currently scheduled to come online in late 2017 and  
27 is a crucial tool for NS Power to meet its 2020 environmental obligations. In addition to

---

<sup>11</sup> Market priced energy is energy priced off of the New England Market at Mass Hub plus applicable transmission, if any, as outlined in slides 60-62 of the Final Assumptions – Appendix B.

1 providing energy, the Maritime Link also provides enhanced interconnection and  
2 opportunities for better regional system cooperation.

3  
4 **3.5 Demand Side Management**

5  
6 ~~Changes to electricity efficiency legislation in Nova Scotia have impacted the analysis of~~  
7 ~~DSM in the 2014 IRP.~~—In order to better integrate DSM within the Candidate Resource  
8 Plan model NS Power used various pre-determined levels of DSM which will inform the  
9 process of contracting with the DSM franchisee contemplated in the revised regulations.  
10 Efficiency Nova Scotia Corp (ENSC) provided the DSM profiles utilized in this planning  
11 exercise through a Potential Study undertaken on their behalf by Navigant Consulting,  
12 Inc. The Company communicated this approach in its April 11 memo to stakeholders<sup>12</sup>  
13 that accompanied the final assumptions:

14  
15 On April 7, 2014, the Province of Nova Scotia introduced Bill No. 41,  
16 Electricity Efficiency and Conservation Restructuring (2014) Act.<sup>13</sup> The  
17 Act, when passed, and the Regulations to be made thereunder, represent a  
18 significant shift in the approach to DSM in the Province. Just as the IRP is  
19 not a regulatory process that determines NS Power's capital spend or  
20 revenue requirements, the IRP is not a regulatory process to determine a  
21 DSM supplier's level, programs or evaluation tests. The proposed  
22 legislation requires NS Power to undertake cost-effective electricity  
23 efficiency and conservation activities that are reasonably available in an  
24 effort to reduce costs for its customers.<sup>14</sup> It provides that in order to meet  
25 this obligation NS Power must contract with the government's approved  
26 franchise holder for the supply of efficiency and conservation programs,  
27 and that such agreement must be approved by the UARB.<sup>15</sup> The Board  
28 shall approve NS Power's agreement with the franchise holder if it is  
29 satisfied that the conservation and efficiency activities that are the subject  
30 of the agreement are in the best interests of customers.<sup>16</sup> The Board's  
31 assessment of the proposed electricity efficiency and conservation

---

<sup>12</sup> [Please refer to Appendix F.](#)

<sup>13</sup> Bill 41, *Electricity Efficiency and Conservation Restructuring (2014) Act*, 1<sup>st</sup> Sess., 62<sup>nd</sup> General Assembly, Nova Scotia, 2014 (First Reading: April 7, 2014).

<sup>14</sup> *Ibid.*, s. 79(I)(1).

<sup>15</sup> *Ibid.*, s. 79(I)(2)(a).

<sup>16</sup> *Ibid.*, s. 79(L)(8).

1 activities for the purpose of the approval must take into account their  
2 affordability to Nova Scotia Power Incorporated's customers, along with  
3 any other matters considered appropriate by the Board or as may be  
4 prescribed.<sup>17</sup>  
5

6 Given the above, NS Power anticipates that the assessment of cost effective DSM  
7 potential will require evaluation as part of a regulatory process ~~as part of or in~~  
8 ~~anticipation of the proceedings~~ to approve NS Power's agreements with the efficiency  
9 and conservation franchise holder in the future.

### 11 3.6 Wind Energy

12  
13 Wind energy variability is reflected in the Strategist model by one representative week  
14 per month compression of observed wind generation shapes. Two other assumptions  
15 regarding wind generation which need to be specified in the model are:

- 16
- 17 1. Capacity value of wind
- 18 2. Integration costs of wind
- 19

20 With significant quantity of wind generation on the system, capacity value or Effective  
21 Load Carrying Capacity (ELCC) of wind generation is a crucial assumption. If ELCC is  
22 assumed to be too high, it can erode system reliability by having too high a contribution  
23 of wind generation to the planning reserve margin. If ELCC is assumed to be too low,  
24 the assumption may drive unnecessary investment in firm capacity in order to meet  
25 planning reserve margin.

26  
27 ELCC of wind was calculated by GE Energy in the Renewable Energy Integration study  
28 commissioned by NS Power and published in June 2013. GE Energy used the Loss of  
29 Load Expectation (LOLE) methodology to calculate the capacity value of wind, based on  
30 a 2006 year wind-load data set which was developed by AWS Truepower from location

---

<sup>17</sup> Ibid, s. 79(L)(9).

1 specific wind speed measurements. GE Energy calculated ELCC of wind to be 27  
2 percent at approximately 585 MW of wind generation on the system, representing the  
3 presently built and committed wind generation in Nova Scotia.  
4

5 Subsequent to publishing the NS Renewable Energy Integration study, GE Energy  
6 identified shortcomings with the LOLE methodology based on a single year's wind-load  
7 data pair. When used on a single year load-wind data set, the LOLE methodology can  
8 yield unreliable conclusions due to widely varying ELCC figures from year to year.  
9

10 GE Energy's subsequent March 2014 analysis of PJM ELCC of wind calculation based  
11 on three years of data, showed widely ranging results of between 8 percent and 44  
12 percent. Please refer to Appendix O (PJM Renewable Integration Study), page 22, figure  
13 1-11.  
14

15 Another example of the same concern with LOLE methodology is the MISO 2014 Wind  
16 Capacity Credit Report which shows ELCC of wind based on 9 years of wind-load data,  
17 ranging from 3 percent to 18 percent. Please refer to Appendix P (MISO 2014 Wind  
18 Capacity Credit Report), page 8, figure 2-3.  
19

20 The graph from MISO report, containing 8 years of wind-load data, was also used by  
21 Synapse in their Technical Training document Session 2: Best and Worst Practices in IRP  
22 and CPCN, in August 2013. Please refer to Appendix Q, page 40.  
23

24 As the industry continues to address the planning questions raised by the integration of  
25 variable generation, some approaches like the single wind-load data set ELCC calculation  
26 employed by GE Energy in the NS Renewable Energy Integration Study are refined to  
27 improve the information provided to system planners and operators.  
28

1 Due to time constraints, the Company was unable to complete a multi-year LOLE study  
2 in order to assess the reliability of LOLE methodology and inform a conclusive selection  
3 of ELCC of wind based on LOLE methodology.  
4

5 NS Power conducted a single year LOLE study in order to validate GE Energy results  
6 and a Cumulative Frequency Analysis study which showed ELCC of wind generation  
7 ranging from four to sixteen percent, depending on the level of confidence.<sup>18</sup> Based on  
8 the referenced studies, NS Power chose ELCC of wind generation to be 12 percent. In  
9 subsequent discussions with Synapse, the Company and Synapse agreed to use 17 percent  
10 ELCC of wind for the purpose of this IRP exercise.  
11

### 12 **3.6.1 NRIS vs. ERIS Interconnected Wind Generation Resources**

13  
14 For the 2014 IRP study simulations, wind generators connected under Network Resource  
15 Interconnection Service (NRIS) were assumed to have a firm capacity value of 17  
16 percent, while the wind generators connected under Energy Resource Interconnection  
17 Service (ERIS): Nuttby Mountain, Dalhousie Mountain and Glen Dhu, were assumed to  
18 have no firm capacity, until further studies can be conducted by the System Operator. All  
19 future wind generation additions up to the contracted 582 MW were assumed to be  
20 connected under NRIS and thus have firm capacity value of 17 percent. The decision to  
21 treat wind generating resources connected under ERIS as having no firm capacity was  
22 consistent with NS Power's planning approach.  
23

24 In order to avoid undue influence of the capacity value of wind selection on the IRP  
25 results, an optimistic capacity value of wind was studied under:  
26

- 27 • A separate CRP dedicated to optimistic capacity value of wind: CRP-9 WIND
- 28 CAP
- 29 • An optimistic Wind Cost/Output sensitivity across all CRPs

---

<sup>18</sup> Please refer to Appendix C.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30

The subject of capacity value of ERIS resources is further discussed in Section 6.4.6.

**3.6.2 Medium and High Wind ELCC Assumptions**

The capacity value of incremental wind additions were taken from the 2013 GE Energy Renewable Energy Integration Study report and were also tested with the Optimistic Wind Cost/Output sensitivity.

**3.6.3 Wind Integration Costs**

Integration costs of a significant quantity of wind generation show up in four major system assumptions:

**1. Effect on generating fleet efficiency**

The costs of wind energy integration reflected in suboptimal hydro fleet dispatch and deterioration of thermal system heat rates were modeled implicitly in Strategist. Additional generating unit start and stops and associated wear and tear were not reflected in the model.

**2. Wind generation curtailment and uneconomic exports**

Strategist does not model wind curtailment. Rather than expressing the costs associated with wind curtailment explicitly and providing it to the Strategist model as an assumption, wind curtailment costs were not modeled, due to the possibility of unduly penalizing wind generation.

**3. Additional system reserve requirement**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

Additional reserve requirement associated with incremental additions of wind generation is not yet known to a sufficient degree for the assumption to be included in the IRP. No additional reserve was assumed for incremental wind additions.

**4. Additional system upgrades to maintain system stability and security**

Wind integration costs of incremental wind additions beyond the presently-installed and committed wind generation associated with system upgrades required to securely integrate further quantities of wind were modeled as an explicit cost associated with each incremental 150 MW wind generation block. Please refer to Appendix D for details.



1 **4.0 ASSUMPTIONS & ANALYSIS PLAN DEVELOPMENT**

2  
3 **4.1 Introduction**

4  
5 In its Terms of Reference, the Company put forward a timeline for the IRP to meet the  
6 directive of the UARB to submit a draft final report for September 30, 2014. That  
7 timeline included the following steps for the development of assumptions and the  
8 Analysis Plan:

- 9  
10 1. Develop criteria for evaluation of various plans and selection of a Preferred  
11 Resource Plan.  
12  
13 2. Identify the major input assumptions which will drive evaluation and selection of  
14 the Preferred Resource Plan.  
15  
16 3. Evaluation of potential resource plans.  
17  
18 4. Select Preferred Resource plan and Develop Action Plan.  
19  
20 5. Prepare final report and Action Plan. File with UARB.  
21

22 On March 7, 2014, NS Power hosted a Technical Conference for participants at which it  
23 reviewed initial draft assumptions and discussed its preliminary thoughts on the Analysis  
24 Plan for the 2014 Integrated Resource Plan (IRP) to obtain feedback from participants.  
25 Final assumptions were developed based on stakeholder feedback and circulated on April  
26 11, with additional final assumptions for wind capacity value and variable generation  
27 integration costs circulated on April 23 and May 1 respectively. Please refer to  
28 Appendices B, C and D for the detailed slide decks of final assumptions.  
29

1 **4.2 Assumptions & Analysis Plan**

2  
3 On March 14, 2014, NS Power circulated draft basic assumptions for feedback. The  
4 Company also circulated additional assumptions details in response to requests from  
5 Larry Hughes, PhD., the Industrial Group and the Nova Scotia Department of Energy.  
6 The March 14 material included a memo<sup>19</sup> describing the 5 steps listed above that NS  
7 Power suggested for the Analysis Plan. That memo contained the following description  
8 of the Analysis Plan:

9  
10 The Analysis Plan strives to;

- 11  
12 i. identify candidate resource plans, including the least cost plan  
13 under the Reference World  
14 ii. identify a reasonable range of foreseeable futures,  
15 iii. evaluate the candidate plans including least cost plans across that  
16 range of futures and  
17 iv. select the Preferred Resource Plan.

18  
19 NS Power has developed the following analysis plan in line with IRP best  
20 practices and will continue to refine its plan based on feedback from  
21 Synapse and Stakeholders. The Company suggests the 5 following steps:

22  
23 **1. Candidate Resource Plans**

- 24 a. Develop a set of candidate resource plans under the  
25 Reference World. Begin with a broad range of draft  
26 resource plans, each developed based on existing resources  
27 and high-level screening of possible resource options.  
28 b. Optimize each draft resource plan under the Reference  
29 World using Strategist. The optimizations would include  
30 the resource options that pass the high level screening. The  
31 results from Strategist will be candidate resource plans.  
32 The results will indicate the relative cost of each resource  
33 plan.

34  
35 **2. Candidate Resource Plan Evaluation**

- 36 a. Run sensitivity tests under the Reference World on each  
37 candidate resource plan from step 1. Strategist may need to  
38 re-optimize certain of the resource plans under certain of

---

<sup>19</sup> Please refer to Appendix E – NS Power memo to stakeholders re: Analysis Plan.

1 the sensitivity tests in order for those plans to meet all  
2 reliability and regulatory constraints.

3  
4 **3. Scenario Testing (“Worlds” Development)**

- 5 a. Develop additional “Worlds” and sensitivities for further  
6 evaluation of the candidate resource plans (a World is a  
7 combination of key assumptions and constraints). This step  
8 includes Worlds of interest to NSPI, Synapse and  
9 Stakeholders.

10  
11 **4. Evaluation and Optimization**

- 12 a. Evaluate the candidate resource plans from step 1 under the  
13 different Worlds and sensitivities. Strategist may need to  
14 re-optimize certain of the resource plans under certain of  
15 the different Worlds in order for those plans to meet all  
16 reliability and regulatory constraints.  
17 b. The results will indicate the expected relative cost of each  
18 resource plan.

19  
20 **5. Preferred Resource Plan Development**

- 21 a. Evaluate performance of resource plans across Worlds and  
22 select Preferred Resource Plan.

23  
24 At this point NS Power will have tested and optimized a number of  
25 candidate resource plans across a range of foreseeable futures, i.e.  
26 “Worlds” based on stakeholder feedback and consultation with Synapse.  
27 NS Power would select its Preferred Resource Plan from among those  
28 candidate plans. The Preferred Resource Plan should have the flexibility  
29 to enable NS Power to meet customer demand and energy requirements,  
30 and environmental obligations in a cost-effective, safe and reliable manner  
31 across a reasonable range of foreseeable futures. This should enable  
32 development of an Action plan for the next 5 years that reflects the type of  
33 “course corrections” that may be required depending on how the world  
34 (e.g., net load, emissions targets, RES requirements) unfolds.<sup>20</sup>  
35

36 On April 11, 2014, based on stakeholder feedback on the draft assumptions, NS Power  
37 supplied Intervenors with the final assumptions for the 2014 IRP developed in  
38 collaboration with UARB Staff and their consultants.<sup>21</sup> In addition, the Company  
39 provided detailed feedback on Intervenor comments on the assumptions with its April 11

---

<sup>20</sup> Appendix E - NS Power Memo to Stakeholders, March 14, 2014.

<sup>21</sup> Please refer to Appendix B.

1 submission. Please refer to Appendices F and G for NS Power’s response to stakeholder  
2 feedback. Intervenors were also given the opportunity to comment on final assumptions  
3 not provided with the April 11 package (capacity value of wind and variable generation  
4 integration costs). The April 11 memo<sup>22</sup> included a brief discussion of NS Power’s  
5 proposed approach to completing the Analysis Plan, specifically to model a limited  
6 number of Candidate Resource Plans, sensitivities and Worlds that bound the wide range  
7 of possible permutations and combinations that have been suggested. The Company  
8 committed to meeting to discuss the Analysis Plan with stakeholders throughout the  
9 modeling phase of the IRP. NS Power held a meeting for customer representatives at its  
10 offices on June 4, 2014 and ENSC on June 20, 2014 to discuss progress on the Analysis  
11 Plan in advance of the scheduled June 25 Technical Conference. The Company provided  
12 an Analysis Plan status update in its memo of June 5, 2014.<sup>23</sup> The Company also made  
13 all IRP information publically available on its website at the following address:

14  
15 [http://www.nspower.ca/en/home/about-us/electricity-rates-and-regulations/regulatory-  
17 initiatives/IRP.aspx](http://www.nspower.ca/en/home/about-us/electricity-rates-and-regulations/regulatory-<br/>16 initiatives/IRP.aspx)

18 On June 25, 2014 the Company hosted its second Technical Conference<sup>24</sup> with  
19 stakeholders. The goal of the consultation was to discuss the Analysis Plan as well as  
20 preliminary results.

### 21 22 **4.3 Candidate Resource Plans**

23  
24 The Candidate Resource Plan component of the 2014 IRP was a change from previous  
25 IRP practices. NS Power discussed how CRPs were selected in its update memo to  
26 stakeholders on July 30, 2014.<sup>25</sup> Candidate Resource Plans are potential IRP plans for  
27 further examination through Strategist modeling and sensitivity analysis. Key

---

<sup>22</sup> Please refer to Appendix F.

<sup>23</sup> Please refer to Appendix H.

<sup>24</sup> Please refer to Appendix I for the presentation materials from the Technical Conference.

<sup>25</sup> Please refer to Appendix J.

1 assumptions are modified to establish different Candidate Resource Plans modifications.  
2 The following excerpt from the July 30, 2014 memo elaborates on how CRPs were  
3 selected:

4  
5 *Basis for selection of initial Candidate Resource Plans (CRPs) from 30*  
6 *draft resource plans*

7  
8 The initial Candidate Resource Plans were selected from the 30 draft  
9 resource plans based on the goal of developing a set of CRPs that span a  
10 reasonable range of plausible resource choices (the IRP Terms of  
11 Reference at page 3 specify that NS Power is to assess "a reasonable, but  
12 not unlimited, number of alternative plans"). The sequence in which NS  
13 Power made this selection, and the criteria it considered at each stage of  
14 the sequence, is summarized below:

- 15  
16 • NS Power, in collaboration with UARB staff and consultants,  
17 began by identifying 30 draft resource plans (see Attachment 1 to  
18 June 5, 2014 memo to stakeholders). Each draft resource plan  
19 began with the existing resources and resource commitments in  
20 effect as of 2015. Those draft resource plans differed in terms of  
21 four major input variables/components that were expected to have  
22 the potential to significantly change the results of the plan (e.g.  
23 revenue requirements, robustness). Those four key input  
24 variables/components were: DSM level, variable generation level  
25 (e.g. wind), fossil unit retirement dates (coal, Tufts Cove) and  
26 potential for a large Power Purchase Agreement (PPA) – please  
27 refer to the June 5th memo to stakeholders and its Attachment 2,  
28 slide 12.  
29  
30 • NS Power then identified five of the 30 draft resource plans to  
31 model in Strategist as initial CRPs under the Reference World.  
32 The initial CRPs were selected to begin developing a set of CRPs  
33 that spanned a reasonable range of plausible, and materially  
34 different, resource choices. They were selected to reflect three  
35 different levels of DSM, two levels of variable generation (e.g.  
36 wind), and two levels of coal retirements. NS Power expected that  
37 the results from modelling these five initial CRPs would help it  
38 determine which of the remaining draft resource plans it would  
39 need to model in order to evaluate a reasonable range of plausible,  
40 and materially different, CRPs and which it would not need to  
41 model because they would not produce materially different results.  
42

## 2014 IRP Final Report

- Based upon the results of modelling the initial five CRPs and upon further examination of the components that can most affect the results of CRPs, NS Power has identified an additional 11 initial CRPs to model under the Reference World. These 11 additional CRPs are included in the list of CRPs described earlier in this memo. These additional initial CRPs were again selected as part of the process to develop a set of CRPs that span a reasonable range of plausible, and materially different, resource choices. The additional 11 CRPs reflect higher levels of wind, earlier coal plant retirement and different DSM levels. They complement the initial five CRPs by representing a further range of differences in levels of DSM, variable generation, levels of coal retirements, Demand response levels, Tufts Cove unit retirements and repowering and PPAs. The Company has also identified two additional CRPs to be modelled under the High Load World.<sup>26</sup>

In total the Company used Strategist to optimize the following 16 resource plans:

CRP	DSM	WIND	COAL
<b>World 1 - REFERENCE</b>			
CRP1-1-FGD	50% of LOW	BASE	MAX
CRP2-1	BASE	BASE	MAX
CRP2-17-FGD	BASE	BASE	MAX
CRP3-1	BASE	MED	MAX
CRP4-1	BASE	BASE	MED
CRP4-1-FGD	BASE	BASE	MED
CRP5-1	HIGH	BASE	MAX
CRP6-1	HIGH	HIGH	MIN
CRP7-1	HIGH	MED	MIN
CRP8-1	BASE	HIGH	MIN
CRP9-1	BASE	MED	MIN
CRP9WC	BASE	MED (Optimistic Capacity Credit)	MIN
CRP10-1	BASE	MED	MED
CRP31-1	BASE - 50% Peak 100% Energy	MED	MAX
<b>World 2- HIGH LOAD</b>			
CRP21-1 (FGD WIND)	BASE	MED (Optimize)	MAX
CRP32-1 (FGD PPA)	BASE -50% Peak 100% Energy	MED (Optimize)	MAX

	Max Retirement Strategy
	Med Retirement Strategy
	Min Retirement Strategy
	Max Retirement Strategy - High Load

<sup>26</sup> Appendix J - NS Power Memo to IRP Stakeholders, July 30, 2014.

1 Note: Maximum retirement strategy indicates the Company plans to maximize utilization  
2 of the units to a 60 year life span. Medium is between 50 and 55 years and Minimum is  
3 around a 40 year life before retirement. [Please refer to Appendix J, pages 15 to 16 for](#)  
4 [details on the retirement strategies assumptions.](#)  
5

#### 6 **4.4 Sensitivity Analysis**

7  
8 In addition to a broad range of initial resource plans NS Power ran a significant number  
9 of sensitivity analyses leading to 76 re-dispatch simulations of the various CRPs:  
10

- 11 • Scenario B emissions – hold emissions at currently legislated levels
- 12 • Scenario C emissions – Reduce CO<sub>2</sub> emissions to 2.25 MT by 2040 and  
13 associated co-benefits
- 14 • High Natural Gas and High Import Power pricing
- 15 • Low Natural Gas and Low Import Power pricing
- 16 • Low International Price of High Sulphur Coal
- 17 • High International Price of High Sulphur Coal
- 18 • Optimistic Wind – low cost, high output wind

#### 19 20 **4.5 Plan Evaluation**

21  
22 Based on the output from the Strategist modeling, NS Power in collaboration with  
23 Synapse and consultation with stakeholders analyzed the results against the following  
24 criterion:  
25

- 26 • *NPV*: Cross-section of near and long term NPVs including end effects NPVs
- 27 • *Rate Effects*: Relative time-series revenue requirements
- 28 • *Future Regulatory emissions outlook*: Results of sensitivity tests
- 29 • *Risk*: Relative complexity and risks inherent in CRPs
- 30 • *Flexibility*: Diversity of technological solutions

- 1           •       *Robustness*: Results of sensitivity tests

2  
3       These metrics include both qualitative and quantitative measures.

- 4  
5           •       *NPV and Rate Effects* – For the NPV and Rate Effects metrics, NS Power  
6       evaluated the NPV of the partial revenue requirements for the planning period  
7       (2015 - 2039) and the shorter term NPV (2015 - 2020) from the Strategist  
8       modeling results. This provides an indication of the performance of the plans  
9       based on the ability to deliver long-term value while giving consideration to near-  
10       term affordability.

- 11  
12          •       *Future Regulatory Emissions Outlook* – For the Future Regulatory Emissions  
13       Outlook metric, the Company looked at a range of emissions constraints. For its  
14       base case (Scenario A) NS Power selected the currently proposed emissions level  
15       over the planning period; sensitivities were run comparing the impact of changing  
16       emissions to lower or higher levels and the impact on the NPVs was analyzed. As  
17       discussed in Section 5, the plan reordering based on emissions scenarios was not  
18       significant.

19  
20       In terms of its assessment of the qualitative metrics listed above – Risk, Flexibility and  
21       Robustness – the Company took a higher level approach. NS Power sought to analyze  
22       the plans to ensure that, while effective from a quantitative perspective, no plan  
23       introduced imbalance from a qualitative perspective. Generally speaking, the plans  
24       performed well qualitatively; this can be seen through the sensitivity analysis discussed in  
25       the next section. The fact that there are no major outliers across the range of sensitivities  
26       speaks to the relative low-risk, robust and flexible nature of the plans.

- 27  
28          •       *Risk* – Risk takes on two dimensions in utility planning; financial risk and  
29       operational risk. Financial risks could be considered the risk that utility spending  
30       to serve forecasted customer needs proves with time to be off target, leaving the



1 utility and its customers exposed to greater-than-anticipated costs. In the window  
2 of the Action Plan, most CRPs have no need for investments in new capital  
3 expansion. DSM programing levels are the largest discretionary consideration  
4 faced in most of the CRPs. One perspective is that choosing not to maximize  
5 DSM spending leaves an opportunity for load reduction unattained. Conversely,  
6 DSM programming has some level of scalability, allowing for a balancing of near  
7 term cost pressure with longer-term efficiency objectives. NS Power proposes  
8 that seeking to find this balance through upcoming contracting discussions with  
9 ENSC mitigates some of the near-term financial risks. Operational risk reflects  
10 the need for the utility to have the proper mix of reliable assets to meet customer  
11 needs for capacity and energy. The NS Power system is in the midst of a major  
12 transformation away from base loaded coal to a broader mix of generation  
13 including renewables. All CRPs share much of the same operational risks in the  
14 near years. Plexos modeling indicates greater operational challenges are faced by  
15 CRPs with higher wind and lighter system load. Certain CRPs presented more  
16 complex (higher risk) solutions than others. Risk across the plans was measured  
17 relative to the plans that had the simplest and most proven solutions implemented  
18 in the near-term period. The Company considered risk over the planning period  
19 to a lesser extent, as future technology changes over the longer period create less  
20 certainty. As a result, plans demonstrating minimal incremental investment over  
21 the short term and a reliance on established technology in the longer term pass the  
22 bar.

- 23  
24 • *Flexibility* – Nova Scotia Power’s generation assets are very diverse with a  
25 capacity mix that includes: coal, petcoke, natural gas, HFO, LFO, hydro and  
26 wind. This diversity will be enhanced by the Maritime Link which brings  
27 augmented market connection. As the system evolves, modeling from this study  
28 suggests that a key focus should be to ensure that it does not become too reliant  
29 on any one supply side or demand side resource to meet its energy and capacity  
30 needs. So, plans that maintained a more diversified portfolio across the planning

1 period were judged favorably to plans that had a heavier reliance on one or two  
2 specific technologies. Plexos modeling indicates the interplay between some of  
3 the resource options. For example in times of heavy wind generation, system load  
4 can be a valuable tool held by a system operator to integrate variable generation.  
5 When wind becomes a large proportion of the instantaneous online generation,  
6 system operators must give consideration to power system inertia, frequency  
7 response and general stability. The ratio of wind generation to load increases  
8 through the development of new wind generation resources, but it also increases  
9 with the reduction of system load through DSM or customer load loss. Put  
10 another way, a barrier to system flexibility could be the reduction of power  
11 system load. Other flexibility considerations come from fuel options. Retiring  
12 coal generation reduces the opportunity to take advantage of possible lower coal  
13 pricing relative to natural gas in this region. Equally true are the inherent  
14 challenges in utilizing conventional steam units in variable generation integration  
15 efforts. The industry is facing the need to repurpose these units on power systems  
16 seeking to integrate greater amounts of non-dispatchable assets. Flue Gas  
17 Desulphurization opens opportunities for higher sulphur domestic fuels with  
18 security of supply, price and economic development advantages, but aggressive  
19 and early DSM spending could be seen as a flexibility measure opening up  
20 opportunities for lower load futures. However, overspending in DSM might  
21 constrain system flexibility by compounding bulk power system operational  
22 challenges that could be introduced by customer self-generation or other load loss  
23 in the future.

- 24  
25 • *Robustness* – NS Power tested a range of sensitivities including pricing and  
26 modified emissions constraints. The results of the sensitivity runs are reflected in  
27 Section 5.5, they show that the plans move relatively uniformly across the  
28 sensitivities. For example the lower cost plans in the base case remain the lower  
29 cost plans across sensitivities and the higher cost plans in the base case remain the  
30 higher cost plans in the sensitivities. Had there been significant swings in the

1 plans across sensitivities, the Company would have had to further examine plan  
2 robustness.

3  
4 Further discussion with stakeholders on evaluation criteria and metrics for choosing a  
5 Preferred Plan took place at the September 12 Technical Conference. The Company  
6 concluded that there are a number of plans with common attributes in the Action Plan  
7 period that should be considered as the Preferred Plan. CPR 2-1 and CRP 5-1 share a  
8 similar resource addition profile out to 2030. The level of DSM spend is the significant  
9 difference in the two plans, but modeling forecasts that neither of the CRPs have capacity  
10 additions during the proposed Action Plan period. These CRPs are robust and flexible as  
11 well as cost effective over both the planning and study periods. NS Power is proposing  
12 that the resource addition profiles from these CRPs represent the most reasonable  
13 planning path until the next IRP. DSM programming levels are to be determined in a  
14 separate regulatory process as per the legislation.

1 **5.0 MODELING RESULTS & PREFERRED RESOURCE PLAN SELECTION**

2  
3 **5.1 Introduction**

4  
5 NS Power started the Candidate Resource Plan screening process with over 30 plans  
6 under consideration. In collaboration with Synapse those plans were screened down to  
7 16 CRPs. The selected plans represent a broad array of considerations and can  
8 reasonably be expected to represent the range of futures that should be considered to plan  
9 for the future electricity system. The main variables in planning the power system for the  
10 next 25 years were considered in the IRP; they include:

- 11  
12 • Load  
13 • DSM  
14 • Unit retirements  
15 • Fuel prices  
16 • Wind levels  
17

18 By changing these assumptions through the various CRPs and sensitivities, the Company  
19 has produced resource plans that can withstand a variety of futures at various costs. For  
20 example, if there are additional renewable requirements, the Company could choose a  
21 high wind CRP; if more DSM is needed, the Company could pick a plan with a higher  
22 DSM investment level.  
23

24 Please refer to Appendix K for a summary of the CRP analysis results. The detailed  
25 modeling results are available in Appendix L. The CRP results generally shared a couple  
26 of common themes; major capacity additions before 2020 were not necessary in the most  
27 economic plans and most plans were similar in NPV over the planning period – most  
28 were within 5 percent of the lowest NPV plan. The Company examined various levels of  
29 wind additions, DSM and coal retirement dates as well as several sensitivities and High  
30 Load World CRPs. The Company’s analysis of the similarity in the planning period NPV

## 2014 IRP Final Report

1 across a number of plans is that previous resource planning has proven robust and should  
 2 allow the electricity system in Nova Scotia to meet its environmental and service  
 3 requirements in a cost effective manner.

4  
 5 Since the 2007 and 2009 IRPs, renewable integration and DSM have been successful  
 6 tools to manage load and green the power system. The following table shows the  
 7 significant changes to the system since the last IRP Update:  
 8

Regulatory and legislative initiatives:		
RES target set at 40% in 2020		
Legislation limiting biomass consumption in the province		
Air emissions equivalency agreement		
Demand and supply side investment:		
DSM Administrator (2008/9 – 2013)	\$165 million	128 MW – 632 GWh
Tufts Cove 6 (HR with duct firing)	\$93 million	49 MW
Port Hawkesbury Biomass	\$209 million	45 MW – 350 GWh
Wind Energy	\$308 million (NSPI)	81 MW – 256 GWh (NSPI) 447 MW – 964 GWh (IPP)
Maritime Link	\$1,500 million	153 MW – 1,000 GWh
System load:		
Loss of industrial load	~165MW – 1,100 GWh	
Industrial load on load retention tariff	~185 MW – 1,050 GWh	
Fuel expense recovery:		
FAM Process instated	Deferred fuel expense: \$89 million	

9  
 10  
 11 The modeling results from this IRP reflect the major changes to the power system since  
 12 2009. With the addition of the Maritime Link, slated to be online in late 2017, the  
 13 Company is well positioned to meet its environmental targets. Results from Strategist  
 14 showed compliance with RES and emissions requirements across all CRPs for the 2020  
 15 period and beyond. The plans with the lowest NPVs over the planning and study periods,  
 16 CRP 2 and CRP 5, did not require capacity additions beyond the Maritime Link pre-2020  
 17 to meet emissions and RES requirements. The following table shows resource additions  
 18 for all plans in the pre-2020 and post-2020 periods.  
 19

## 2014 IRP Final Report

**Candidate Resource Plans - Schedule of Changes to Supply-side and Demand-side Resources (Firm MWs)**

	CRP1-1 FGD	CRP2-1	CRP2-17 FGD	CRP3-1	CRP4-1	CRP4-1 FGD	CRP5-1	CRP6-1	CRP7-1	CRP8-1	CRP9-1	CRP9WC*	CRP10-1	CRP31-1	CRP21-1 (FGD WIND)	CRP32-1 (FGD PPA)
<b>Load</b>	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	High	High
<b>DSM Profile</b>	Half Low	Base	Base	Base	Base	Base	High	High	High	Base	Base	Base	Base	Base	Base	Base
<b>Wind</b>	Base	Base	Base	Med	Base	Base	Base	High	Med	High	Med	Med	Med	Med	Med	Base
<b>Retirement Strategy</b>	Max	Max	Max	Max	Med	Med	Max	Min	Min	Min	Min	Min	Med	Max	Max	Max
<b>New Resources 2015-2020</b>																
DSM	62	156	156	156	156	156	241	241	241	156	156	156	156	80	156	80
Maritime Link	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153	153
DR	0	0	0	0	19	19	0	0	19	10	19	19	19	0	0	10
Mersey	15	0	0	0	0	0	0	0	0	15	15	15	15	0	15	0
Wind	0	0	0	0	0	0	0	0	0	0	0	70	0	0	18	0
PPA	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	100
PHBM	0	0	0	0	0	0	0	52	52	52	52	52	0	0	0	0
NG CT	0	0	0	0	0	0	0	0	0	0	0	0	0	0	99	0
NG CC	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
FGD	0	0	0	0	0	0	0	0	0	0	0	0	0	0	-8	-8
<b>Retirements</b>																
Coal	-153	-153	-153	-153	-153	-153	-153	-306	-306	-306	-306	-306	-306	-153	-153	-153
NG/Oil	0	0	0	0	-81	-81	0	0	0	0	0	0	0	0	0	0
<b>Subtotal</b>	<b>77</b>	<b>156</b>	<b>156</b>	<b>156</b>	<b>94</b>	<b>94</b>	<b>241</b>	<b>140</b>	<b>159</b>	<b>80</b>	<b>89</b>	<b>158</b>	<b>190</b>	<b>80</b>	<b>280</b>	<b>182</b>
<b>New Resources 2021-2039</b>																
DSM	202	510	510	510	510	510	643	643	643	510	510	510	510	254	510	254
DR	0	0	0	0	67	67	0	0	67	52	67	67	67	0	0	52
Mersey	15	0	0	0	0	0	0	0	0	15	15	15	15	0	15	0
Wind	0	0	0	18	0	0	0	36	18	36	18	36	18	18	0	0
PPA	100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PHBM	52	52	52	52	0	0	52	0	0	0	0	0	52	52	45	45
NG CT	315	99	149	99	216	99	0	296	197	444	296	364	265	330	148	397
NG CC	145	0	0	0	290	145	0	0	0	0	145	0	0	145	0	145
FGD	-8	0	-8	0	0	-8	0	0	0	0	0	0	0	0	0	0
<b>Retirements</b>																
Coal	-303	-303	-303	-303	-614	-303	-303	-613	-613	-613	-613	-613	-613	-614	-303	-303
NG/Oil	-174	-174	-174	-174	-240	-240	-174	-174	-174	-174	-174	-174	-174	-174	-174	-174
<b>Subtotal</b>	<b>344</b>	<b>183</b>	<b>226</b>	<b>201</b>	<b>229</b>	<b>270</b>	<b>218</b>	<b>188</b>	<b>138</b>	<b>270</b>	<b>264</b>	<b>205</b>	<b>139</b>	<b>322</b>	<b>242</b>	<b>417</b>
<b>Total Additional Firm Supply &amp; Demand MW's Over Planning Period</b>																
<b>Total</b>	<b>421</b>	<b>340</b>	<b>382</b>	<b>358</b>	<b>323</b>	<b>364</b>	<b>459</b>	<b>328</b>	<b>297</b>	<b>350</b>	<b>353</b>	<b>364</b>	<b>329</b>	<b>402</b>	<b>521</b>	<b>599</b>

**Notes for Schedule of Changes to Supply-side and Demand-side Resources (Firm MWs):**


- DSM - capacity refers to reduction in firm demand (net of interruptible industrial portion)
- DR (Demand Response) - capacity refers to reduction in firm demand
- Mersey - incremental capacity upgrade
- Wind - firm contribution of incremental wind above planned and committed wind of 582 MW
  - \* for CRP 9 WC the firm contribution of planned /committed wind and incremental wind was increased to 24.1 percent.
- PPA - Large non-emitting, RES compliant Purchased Power Agreement
- PHBM - PH Biomass unit is assumed to transition to a firm capacity resource upon the retirement of a second Lingan unit
- NG CT - Natural Gas Combustion Turbine
- NG CC - Natural Gas Combined Cycle
- FGD - coal retrofit with an FGD (scrubber) results in reduced capacity due to parasitic power

As indicated in the table above, apart from investment in Demand Response, incremental Mersey capacity and a change to the Port Hawkesbury biomass facility from Energy Resource Interconnection Service to Network Resource Interconnection Service, there is no call for new capacity in the next 5 years under any of the 14 CRPs for the Reference World. The resources the system needs to serve load over the near term period are in

place and available. The key variable, from a planning perspective, for the Reference World over the near term period is the level of DSM.

5.2 DSM

The range of DSM levels modeled was derived from the most recent Efficiency Nova Scotia Corporation DSM Potential Study and was intended to reflect a wide range of potential DSM outcomes. The graph below shows the various DSM impacts assumed across the CRPs. Base DSM is the base amount from the ENSC potential study, High is the amount assumed in the high case of that same study and Half Low is 50 percent of the low range of the study. Current energy savings and investment in DSM was set at \$35 million for 2015, producing an energy savings of 121 GWh. This level was established by the government of Nova Scotia in the Electricity Efficiency and Conservation Restructuring (2014) Act. The investment levels for the High, Base and Half Low cases are roughly \$100 million, \$50 million and \$25 million respectively and are reflected in the graph labelled “DSM Program Administrator Costs” on page 56.



## 2014 IRP Final Report

### 5.3 Thermal Fleet

The CRPs with the lowest planning period NPVs (CRP 2 and CRP 2-17 FGD) both had coal retirements occurring at 60 years, demonstrating that delaying retirement of existing coal assets is the lowest cost option for customers. This is the case across all sensitivities, as can be seen from the table below, CRP 2 and CRP 2-17 consistently rank 1 and 2 in planning period NPV across the scenarios considered. 60 year retirements represent the optimal economic life of the units from the analysis of the Company’s asset management team. Apart from Lingan 2 which retires when the Maritime Link comes in service, there are no scheduled coal plant retirements in the lowest NPV plans until post 2020. Such a strategy will require ongoing asset management efforts to mitigate the risks associated with the transition away from base loaded operation to more of a load-following dispatch.

These results include the NPV adders for Sustaining Capital  
Study period NPV's can only be compared within the same unit retirement strategies (e.g. all maximum coal)

50% Low DSM
High DSM
Base DSM
Base DSM- 50% PEAK, 100% ENERGY
Cost unchanged from Original Case

All Values in \$M	Original Data		S1 - Emissions B		S2 - Emissions C		S3 - High NG & IMPORT Prices		S4 - Low NG & IMPORT Prices		S6 - Low Price High S Coal		S7 - High Price High S Coal		S9 - Optimistic Wind-cost-output	
	Planning Period Cost	Study Period Cost	Planning Period Cost	Study Period Cost	Planning Period Cost	Study Period Cost	Planning Period Cost	Study Period Cost	Planning Period Cost	Study Period Cost	Planning Period Cost	Study Period Cost	Planning Period Cost	Study Period Cost	Planning Period Cost	Study Period Cost
<b>World 1 - REFERENCE</b>																
CRP1-1-FGD	\$12,449	\$19,774	\$12,370	\$19,617			\$13,166	\$21,288	\$11,899	\$18,331	\$12,372	\$19,600	\$12,619	\$20,203	\$12,449	\$19,774
CRP2-1	\$11,544	\$17,103	\$11,405	\$16,802	\$11,551	\$17,192	\$12,097	\$18,216	\$11,090	\$15,993	\$11,544	\$17,103	\$11,544	\$17,103	\$11,544	\$17,103
CRP2-17-FGD	\$11,530	\$17,200	\$11,489	\$17,102	\$11,580	\$17,391	\$11,996	\$18,280	\$11,157	\$16,259	\$11,460	\$17,093	\$11,704	\$17,484	\$11,530	\$17,200
CRP3-1	\$11,825	\$17,419	\$11,704	\$17,150			\$12,308	\$18,392	\$11,406	\$16,412	\$11,825	\$17,419	\$11,825	\$17,419	\$11,742	\$17,199
CRP4-1	\$11,736	\$17,643	\$11,609	\$17,436	\$11,743	\$17,686	\$12,309	\$18,807	\$11,253	\$16,258	\$11,736	\$17,643	\$11,736	\$17,643	\$11,736	\$17,643
CRP4-1-FGD	\$11,692	\$17,469	\$11,654	\$17,343	\$11,734	\$17,594	\$12,156	\$18,563	\$11,305	\$16,401	\$11,622	\$17,326	\$11,863	\$17,713	\$11,692	\$17,469
CRP5-1	\$12,125	\$17,076	\$12,027	\$16,849			\$12,548	\$17,900	\$11,746	\$16,185	\$12,125	\$17,076	\$12,125	\$17,076	\$12,125	\$17,076
CRP6-1	\$12,638	\$17,829	\$12,617	\$17,808	\$12,638	\$17,829	\$13,110	\$18,735	\$12,264	\$16,965	\$12,638	\$17,829	\$12,638	\$17,829	\$12,478	\$17,405
CRP7-1	\$12,512	\$17,666	\$12,479	\$17,633			\$13,016	\$18,653	\$12,108	\$16,727	\$12,512	\$17,666	\$12,512	\$17,666	\$12,430	\$17,452
CRP8-1	\$12,240	\$18,095	\$12,205	\$18,059	\$12,240	\$18,095	\$12,811	\$19,263	\$11,784	\$16,991	\$12,240	\$18,095	\$12,240	\$18,095	\$12,075	\$17,651
CRP9-1	\$12,200	\$18,091	\$12,158	\$18,049	\$12,200	\$18,091	\$12,824	\$19,396	\$11,680	\$16,770	\$12,200	\$18,091	\$12,200	\$18,091	\$12,117	\$17,870
CRP9WC	\$12,101	\$17,968	\$12,059	\$17,926	\$12,101	\$17,968	\$12,718	\$19,281	\$11,600	\$16,736	\$12,101	\$17,968	\$12,101	\$17,968	\$12,017	\$17,742
CRP10-1	\$12,000	\$17,731	\$11,904	\$17,566			\$12,490	\$18,733	\$11,576	\$16,694	\$12,000	\$17,731	\$12,000	\$17,731	\$11,919	\$17,515
CRP31-1	\$11,934	\$17,831	\$11,815	\$17,563			\$12,424	\$18,822	\$11,505	\$16,690	\$11,934	\$17,831	\$11,934	\$17,831	\$11,856	\$17,620
<b>World 2 - HIGH LOAD</b>																
CRP21-1 (FGD)	\$13,071	\$19,852	\$12,990	\$19,712	\$13,157	\$20,289	\$13,706	\$21,267	\$12,593	\$18,690	\$12,962	\$19,685	\$13,322	\$20,246	\$12,979	\$19,624
CRP32-1 (FGD PPA)	\$13,256	\$20,585	\$13,166	\$20,389			\$14,056	\$22,161	\$12,697	\$19,067	\$13,143	\$20,371	\$13,508	\$21,084	\$13,256	\$20,585


What can also be seen from the table above is that in several cases, and in the High Load World, flue gas desulphurization (FGD) technology appears to be an economic investment. FGD is an emission control technology fitted to the coal fired generating units to remove most of the sulphur dioxide from boiler flue gases prior to release to the atmosphere. Utilization of FGD technology allows for the combustion of generally high sulphur, lower cost fuels (coal and petcoke). This could introduce the opportunity of



1 domestic high sulphur coals, provided that the source presented a cost effective option.  
2 The Company is proposing to study this further in the context of solid fuel pricing as part  
3 of its Action Plan. As can be seen in the schedule of changes to supply, there are  
4 capacity additions in the high load scenarios before 2020 and the Company anticipates  
5 that if energy demand or peak demand exceed the base levels forecast or DSM does not  
6 perform then capacity additions either via a PPA or natural gas combustion turbines may  
7 be necessary.  
8

9 **5.4 Renewables**

10  
11 Several different levels of renewable generation were assumed in the IRP: existing and  
12 committed wind generation of 582 MW (Base), and two incremental levels of wind  
13 addition bring the installed total to 750 MW (Medium) and 900 MW (High).  
14 Assumptions included incremental capital investments for system reliability to manage  
15 wind cases of 750 MW and 900 MW. Plexos modeling was used to evaluate dispatch  
16 and operating challenges associated with some of the selected CRPs. This work revealed  
17 that wind generation above base levels<sup>27</sup> when combined with significant DSM  
18 programing could result in significant uneconomic exports and wind curtailments.  
19



20  
<sup>27</sup> Base levels are the 582 MW currently planned or under development and included in slide 34 of the presentation given at the June 25, 2014 Technical Conference.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30

The Company continues to gain firsthand experience with the integration of wind generation on the power system. Accordingly, the Company proposes to report on the ongoing integration experience of variable renewable generation as part of its Action Plan.

The basic assumptions also called for the Mersey system redevelopment as a feature that was included across all plans. Strategist was then given the option to select 2 blocks of 15 MW capacity additions associated with the Mersey system upgrades, as when the refurbishment occurs it has been estimated that there could be a capacity increase of 30 MW.

The Maritime Link is scheduled to come online in the first 5 years of the IRP. The Company has a number of transmission projects related to the Maritime Link that will be implemented prior to the completion of the Link. NS Power also expects that the Link will bring opportunities for enhanced regional coordination and integration. This enhanced interconnection will also enable better access to markets for imports and exports.


**5.5 Sensitivities and Worlds**

Nova Scotia Power ran the following sensitivities:

- Deeper emissions cuts
- Less emissions cuts
- High natural gas, high import power pricing
- Low natural gas, low import power price
- No Demand Response Programs
- Low international price for high sulphur coal
- High international price for high sulphur coal

- Low cost, high output wind

The whisker graph below shows that CRPs performed similarly across the various sensitivities. This shows that the resource mix for supplying the Nova Scotia system is robust. The diversified portfolio of options includes; coal, natural gas, oil, biomass, hydro, wind, Maritime Link and DSM. Having such a diversified system provides a natural hedge so if one commodity spikes there isn't necessarily a system wide impact.



## 5.6 Evaluation of Alternative CRPs

NS Power evaluated the suite of CRPs using planning period NPV and rate impact as the primary criteria to judge the various plans. However the Company also considered Risk, Flexibility, Robustness and Future Regulatory Emissions Outlook as qualitative screens to ensure that the chosen path could maintain the characteristics of previous IRPs and be a “no regrets” solution.

The various DSM profiles result in a range of nearly 3,000 GWh by the end of the study period, roughly 25 percent of the annual energy in the high load case. There is also a significant difference in the NPVs, and therefore potentially the revenue requirements, of

## 2014 IRP Final Report

the various DSM profiles over the short, medium and long terms respectively. The following table shows the NPVs of all plans across 4 periods.

- to 2020 (5 years)
- to 2030 (15 years)
- to 2039 (Planning Period)
- beyond 2039 (Study Period)

	CRP1-1 FGD	CRP2-1	CRP2-17 FGD	CRP3-1	CRP4-1	CRP4-1 FGD	CRP5-1	CRP6-1	CRP7-1	CRP8-1	CRP9-1	CRP9WC	CRP10-1	CRP31-1	* CRP21-1 (FGD WIND)	* CRP32-1 (FGD PPA)
<b>Load DSM Profile</b>	Base Half Low	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	Base	High	High
<b>Wind</b>	Base	Base	Base	Med	Base	Base	Base	High	Med	High	Med	Med	Med	Med	Med	Base
<b>Retirement Strategy</b>	Max	Max	Max	Max	Med	Med	Max	Min	Min	Min	Min	Min	Med	Max	Max	Max
<b>TRC \$ M</b>																
<b>NPV 2020</b>	\$3,907	\$4,049	\$4,049	\$4,049	\$4,065	\$4,065	\$4,491	\$4,489	\$4,507	\$4,062	\$4,072	\$4,072	\$4,075	\$4,050	\$4,194	\$4,195
<b>NPV 2030</b>	\$9,025	\$8,777	\$8,780	\$8,959	\$8,836	\$8,838	\$9,547	\$9,864	\$9,790	\$9,203	\$9,182	\$9,113	\$9,063	\$8,963	\$9,764	\$9,761
<b>Planning Period</b>	\$12,449	\$11,544	\$11,530	\$11,825	\$11,737	\$11,693	\$12,125	\$12,638	\$12,512	\$12,240	\$12,200	\$12,101	\$12,000	\$11,933	\$13,070	\$13,256
<b>** Study Period</b>	\$19,775	\$17,103	\$17,201	\$17,419	\$17,643	\$17,469	\$17,076	\$17,829	\$17,666	\$18,095	\$18,091	\$17,968	\$17,731	\$17,831	\$19,851	\$20,585
<b>TRC Rank</b>																
<b>NPV 2020</b>	1	3	2	3	7	7	13	12	14	6	9	9	11	5	1	2
<b>NPV 2030</b>	7	1	2	5	3	4	12	14	13	11	10	9	8	6	2	1
<b>Planning Period</b>	12	2	1	5	4	3	9	14	13	11	10	8	7	6	1	2
<b>Avg. Rank</b>	6.7	2.0	1.7	4.3	4.7	4.7	11.3	13.3	13.3	9.3	9.7	8.7	8.7	5.7	1.25	1.75
<b>** Study Period</b>	6	2	3	4	2	1	1	2	1	5	4	3	3	5	1	2
<b>Utility Cost \$ M</b>																
<b>NPV 2020</b>	\$3,784	\$3,858	\$3,857	\$3,858	\$3,874	\$3,874	\$4,054	\$4,051	\$4,069	\$3,871	\$3,880	\$3,880	\$3,883	\$3,859	\$4,002	\$4,003
<b>NPV 2030</b>	\$8,762	\$8,416	\$8,420	\$8,599	\$8,475	\$8,478	\$8,672	\$8,989	\$8,915	\$8,843	\$8,822	\$8,753	\$8,703	\$8,603	\$9,403	\$9,401
<b>Planning Period</b>	\$12,086	\$11,069	\$11,055	\$11,350	\$11,262	\$11,218	\$11,087	\$11,601	\$11,475	\$11,765	\$11,725	\$11,626	\$11,525	\$11,458	\$12,595	\$12,781
<b>** Study Period</b>	\$19,270	\$16,471	\$16,568	\$16,786	\$17,010	\$16,836	\$15,846	\$16,599	\$16,436	\$17,462	\$17,458	\$17,336	\$17,098	\$17,198	\$19,219	\$19,953
<b>Utility Cost Rank</b>																
<b>NPV 2020</b>	1	3	2	3	7	7	13	12	14	6	9	9	11	5	1	2
<b>NPV 2030</b>	10	1	2	5	3	4	7	14	13	12	11	9	8	6	2	1
<b>Planning Period</b>	14	2	1	6	5	4	3	10	8	13	12	11	9	7	1	2
<b>Avg. Rank</b>	8.3	2.0	1.7	4.7	5.0	5.0	7.7	12.0	11.7	10.3	10.7	9.7	9.3	6.0	1.25	1.75
<b>** Study Period</b>	6	2	3	4	2	1	1	2	1	5	4	3	3	5	1	2

Max Retirement Strategy
  Med Retirement Strategy
  Min Retirement Strategy

This table shows that from an NPV perspective, 4 plans with 3 different DSM profiles emerge as the low-cost plan depending on the timeframe:


- to 2020 (5 years) – CRP 1-1 FGD
- to 2030 (15 years) – CRP 2-1
- to 2039 (Planning Period) – CRP 2-17 FGD
- beyond 2039 (Study Period) – CRP 5-1

## 2014 IRP Final Report

1 These plans share common assumptions for wind levels and retirement strategies – base  
 2 wind levels and maximizing the life of NS Power’s coal fleet. However, these plans vary  
 3 in their DSM investment:

- 5 • CRP 1-1 FGD – 50% of low
- 6 • CRP 2-1 – Base
- 7 • CRP 2-17 FGD – Base
- 8 • CRP 5-1 – High

9  
 10 The following graphs show the variation in NPVs based on DSM profiles across the  
 11 periods:



15 **DSM load comparison**  
 16 ■ Half Low ■ Base ■ High ■ Base 50% Peak 100% Energy

17 The percentages on the charts represent what percentage the plans’ respective NPV is  
 18 higher than the plan with the lowest NPV in that period. While the IRP is a long-term  
 19 planning exercise, it can provide an indication of potential rate pressures for the near term

## 2014 IRP Final Report


through partial revenue requirements produced by the modeling. Partial revenue requirements include the following:

- fuel and purchased power
- thermal and hydro unit O&M
- capital costs for new resources added in the CRP
- DSM program administrator costs
- sustaining capital costs for existing and new generation added in the CRP

Strategist revenue requirements do not include the following:


- remaining O&M
- regulatory adjustments/amortizations,
- depreciation, interest and tax impacts for existing assets
- T&D sustaining capital cost

The following graph illustrates the revenue requirements compared against CRP 2, the lowest cost plan over the planning period:



1  
2  
3  
4  
5  
6  
7

In the near-term, low DSM investment produces the lowest revenue requirement and potentially the least rate pressure. Alternatively, High DSM produces the highest revenue requirement in the near-term but the lowest in the final years of the planning period. This should be expected as the graph below shows the difference in investment in DSM between the various cases, close to \$100 million in revenue requirement in some years.




8  
9  
10  
11  
12  
13  
14  
15  
16  
17

As part of its Action Plan, NS Power will work with ENSC and stakeholders to determine the optimal level of DSM spend that balances short term affordability<sup>28</sup> with long term performance.

DSM levels in the planning period also have a significant impact on planning reserve margin. The graph below demonstrates that some CRPs have much higher levels of planning reserve margin than the 20 percent reserve margin requirement.

<sup>28</sup> Affordability as referenced in Bill 41, Electricity Efficiency and Conservation Restructuring (2014) Act, 1<sup>st</sup> Sess., 62<sup>nd</sup> General Assembly, Nova Scotia, 2014 (First Reading: April 7, 2014).



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20

The Company has committed to studying levels of sustaining capital that could, if necessary, reduce the level of surplus planning reserve margin in the event of lower firm peak load. ~~NS Power will also produce a report on industry best practices regarding sustaining capital.~~ Sustaining capital as discussed in the IRP is the investment the Company makes on an annual basis to maintain over 1500 MW of firm thermal generating capacity. The estimates of sustaining capital required for the planning period were derived for the different fleet utilization strategies and expressed as a net present value of approximately \$300 million dollars. Having excess planning reserve margin could mean that capacity could be retired therefore reducing the amount of sustaining capital required. But like DSM investment, discrete retirement strategies were selected for modeling and were not optimized in the CRP process. Further work will be undertaken within the Action Plan to refine and report on unit retirement forecasts.

**5.7 Preferred Plan**

As indicated, the IRP is a 25 year planning exercise but the various plans perform differently at different time intervals within and beyond that period. The top performing plans from a planning period NPV perspective have similar attributes – they utilize



## 2014 IRP Final Report

---

1 existing coal units to their maximum lifespans, there is no incremental variable  
2 generation added and new thermal generation, if any, is natural gas combustion turbines.

3  
4 The Company believes that maximizing coal plant life, not adding incremental variable  
5 generation, and a focus on affordability to be a no regrets path and has tried to reflect that  
6 in the Action Plan. So while in past IRPs the Company would have selected a certain  
7 plan to base its Action Plan on, the range of reasonable futures and therefore plans seems  
8 to have converged significantly around a strategy of minimal incremental capital  
9 expenditure, especially in the near term.

10  
11 The notable exception to this trend of convergence and minimal investment is DSM. The  
12 low DSM plan has the best NPV in the near term, the base DSM plan has the best NPV in  
13 the 25 years of the planning period, and high levels of spending on DSM show the best  
14 NPV in the long term period, while exerting the highest rate pressure in the near term.  
15 The Company feels that the IRP process has identified the appropriate range of DSM to  
16 acquire over the planning period from a planning perspective. Given the Electricity  
17 Efficiency and Conservation Restructuring Act, which received Royal Assent on May 1,  
18 2014, NS Power expects to establish the specific level of DSM to acquire during the  
19 Action Plan period in a separate proceeding. The Act calls for NS Power to contract with  
20 the electricity efficiency and conservation franchise holder over the next ten years in  
21 three year terms, the first term beginning in 2016. This will enable NS Power to work  
22 with ENSC and stakeholders to establish a proposal for the level of DSM that considers  
23 the long term benefits of DSM in conjunction with affordability considerations as  
24 outlined in its Action Plan.

1 **6.0 ACTION PLAN**

2  
3 **6.1 Action Plan Introduction**

4  
5 The intent of the Action Plan is to provide the UARB, NS Power and stakeholders with a  
6 guideline for system planning over the next five years. The Action Plan also serves to  
7 inform the next IRP by studying key findings from the analysis phase of this IRP. There  
8 are action items pertaining to DSM, renewables, regional integration, sustaining capital,  
9 transmission and capacity reserve margin.

10  
11 **6.2 2014 IRP Action Items**

12  
13 The 2014 IRP Action Plan identifies specific actions the Company will take over the next  
14 five years. Action items are based on the type and timing of resources identified in the  
15 least cost plans from analysis completed over the course of the IRP modeling, and  
16 feedback received from stakeholders throughout the IRP process. The directed actions  
17 also recognize the limitations of the modeling processes used, and reflect NS Power's  
18 understanding of additional analytical efforts required to sufficiently address certain areas  
19 of inquiry.

20  
21 **6.2.1 Demand Side Management**

22  
23 Changes to electricity efficiency legislation in Nova Scotia have impacted the analysis of  
24 DSM in the 2014 IRP. In order to evaluate DSM programming within the Candidate  
25 Resource Plan model, various pre-determined levels of DSM were used. These levels  
26 will inform the process of contracting with the DSM franchisee contemplated in the  
27 revised legislation. NS Power therefore proposes to work with ENSC and stakeholders to  
28 obtain a cost-effective and affordable level of DSM consistent with the IRP findings, to  
29 be submitted to the UARB for approval in accordance with the revised DSM legislation.

### Demand Side Management Actions:

- Engage with ENSC and stakeholders to develop a three year plan and file for UARB approval: first half of 2015.
- Obtain DSM resource commitments (annual system energy and peak period capacity reductions) for the 2016-2018 period that are consistent with the IRP analysis.
- Engage with stakeholders and ENSC to monitor DSM performance and options: Q4, 2014, Q1, 2015.
- During 2015, determine whether evaluation, monitoring and verification will be sufficient to establish the savings impacts of DSM resources going forward, including commitments for the period 2016-2018.
- Pursue cost-effective Demand Response opportunities: ongoing.

### 6.2.2 Renewable Resources

Several different levels of renewable generation were assumed in the IRP: 582 MW (Base), 750 MW (Medium), and 900 MW (High). Wind levels above currently planned capacity additions when combined with medium and early coal retirement dates could result in uneconomic exports and additional wind curtailments. However, the IRP studies do not explicitly account for the potential of mitigating factors (such as infrastructure investment, and increased regional cooperation) to manage such concerns. Action Plan items will address this.

The Maritime Link is scheduled to come online in the first five years of the IRP. The Company has a number of transmission projects related to the Maritime Link that will be

1 implemented prior to the completion of the Link. NS Power also expects that the Link  
2 will bring opportunities for enhanced regional coordination and integration. This  
3 enhanced interconnection will also enable better access to markets for imports and  
4 potentially exports.

5  
6 The basic assumptions also called for the Mersey system redevelopment as a feature that  
7 was included across all plans. Strategist was then given the option to select 2 blocks of  
8 15 MW capacity additions associated with the Mersey system upgrades as when the  
9 refurbishment occurs it has been estimated that there could be a capacity increase of  
10 30MW. As noted elsewhere, since the Strategist modeling process did not economically  
11 optimize capacity contributions from different resources, the extent to which the Mersey  
12 system increment could be a cost-effective capacity contribution to NS Power's system is  
13 still to be determined through a UARB process if the Company makes application for the  
14 upgrades.

15  
16 NS Power recognizes there are challenges and opportunities over the course of the Action  
17 Plan period concerning the integration of renewable energy and proposes the following  
18 action items.

19  
20 **Renewable Resource Actions:**

- 21
- 22 • During 2015-2016, continue to evaluate the coincidence of wind generation with  
23 peak load to better understand the capacity value of wind assets on the NS Power  
24 system.
  - 25
  - 26 • Monitor ongoing developments of tidal energy and report to the UARB as part of  
27 the 10 Year System Outlook Report filed annually in June.
  - 28
  - 29 • Complete the integration of the Maritime Link.
  - 30

- 1       • Evaluate the options for Mersey Hydro System redevelopment and file an  
2       Application with the UARB, inclusive of both existing capacity and potential  
3       capacity expansions. Conduct further analysis to understand the value of  
4       incremental capacity associated with the Mersey redevelopment, accounting for  
5       the value of small-scale capacity additions, possible different thermal plant  
6       retirement paths (thus affecting the need for a Mersey increment), the flexibly  
7       dispatchable nature of a Mersey hydro increment, and the lack of emissions  
8       associated with any increase in hydro development.  
9
- 10       • Continue to develop an understanding of the operational challenges associated  
11       with the planned increasing levels of variable generation integration and report to  
12       the UARB as part of the 10 Year System Outlook Report.  
13
- 14       • File Renewable to Retail Tariff Application by September 1, 2015.  
15
- 16       • Report to the UARB on the status of the need for flexible resources to integrate  
17       additional variable generation in the 10 Year System Outlook Report.  
18

### 19   **6.2.3 Regional Opportunities**

20

21       The Maritime Link is scheduled to come online in 2017 and is a crucial tool for NS  
22       Power to meet its 2020 environmental obligations. In addition to providing energy, the  
23       Maritime Link also provides enhanced interconnection and opportunities for better  
24       regional system cooperation. There is also greater interconnection and cooperation  
25       possibilities with New Brunswick, the Company would like to further consider these  
26       opportunities through the Action Plan period.  
27

28       The IRP modeling process did not include explicit modeling of the potential benefits of  
29       greater levels of regional cooperation, as the work focused primarily on in-province  
30       actions.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29

**Regional Opportunities Actions:**

- Monitor cost-effective market opportunities (imports and exports) as well as enhancements in regional balancing and interconnection and report on developments in the 10 Year System Outlook Report.
  
- During 2015, continue discussions with Newfoundland (NALCOR) and New Brunswick (New Brunswick Power) on greater regional electric system coordination.
  - Provide an annual update to the UARB.
  
  - Discuss need, impacts, and cost allocation associated with a second 345 kV line to New Brunswick.
  
  - Explore mechanisms to advance efficient regional unit commitment, dispatch, and operating reserve sharing policies.
  
  - Examine the effects of the operation of the Maritime Link on these issues.

**6.2.4 Existing Thermal Resources**

CRPs with lower planning period NPVs generally reflect “maximum coal” utilization inputs to Strategist, indicating the potential value of extending coal plant asset life in order to meet planning reserve requirements. However, since Strategist does not optimize plant retirement, the modeling results do not provide absolute clarity on the most economic retirement or plant life extension path for the thermal units.

1 In several cases, and in the High Load World CRPs, flue gas desulphurization appears to  
2 be an economic investment. The Company is proposing to study this further in the  
3 context of solid fuel pricing.  
4

5 Over the study period CRP 5-1 had the lowest NPV; it was also competitive over the  
6 planning period. CRP 5-1 and other CRPs had excess capacity margin, as a result of the  
7 modeling technique, indicating that there may be opportunity to optimize asset  
8 management over the planning period to reduce spare capacity reserve. NS Power  
9 proposes to further study its asset management practices and sustaining capital spend  
10 within the context of the Action Plan.  
11

### 12 **Existing Thermal Resources Actions:**

- 13  
14 • Continue the thermal generation asset analysis work from the IRP process. By the  
15 end of June 2015, file an initial thermal asset management plan striving to  
16 optimize the level of sustaining capital expenditures required for the fleet of  
17 coal/oil/gas plant. Update this plan each year in the 10 Year System Outlook  
18 Report. The plan will include the following:  
19
  - 20 • Recognition of uncertainty of many elements involved in this form of  
21 analysis.  
22
  - 23 • Recognition of/adherence to planning reserve margin requirement and  
24 level of planning reserve surplus associated with different net firm peak  
25 load trajectories based on then-anticipated DSM peak reductions and  
26 associated net firm peak load forecast.  
27
  - 28 • Projections of possible retirement paths for the thermal fleet.  
29
  - 30 • Prioritization of units or plans for retention given system constraints.

- 1
- 2           •       Consideration of locational value of Tufts Cove plant, and flexible
- 3                   operating characteristics of gas and oil-fired steam units compared to coal-
- 4                   fired units. There may be locational or system considerations that could
- 5                   give preference to sustaining capital or life extension expenditures at the
- 6                   Tufts Cove location compared to other plants.
- 7
- 8           •       Consideration of location of other system resources, either NS Power-
- 9                   owned or IPP-owned, and their capacity value.
- 10
- 11          •       Consideration of unit utilization forecasts and the significant driver that
- 12                   operating hours is for maintenance investment.
- 13

14           Ultimately, this Action Plan item will result in an analysis of investment plans for

15           the existing thermal fleet given forecasted system peak and unit utilization. Based

16           on the modeling results, high DSM plans can lead to excess planning reserve

17           margin if no changes are made to the coal utilization path modeled; this may also

18           be the case with base-level DSM resource commitments.

19

- 20          •       Provide an outlook of sustaining capital expenditures for thermal assets for a five
- 21                   year period in the Annual Capital Expenditure Plan.
- 22
- 23          •       Study the economic potential of an FGD in combination with opportunities to
- 24                   optimize solid fuel use.
- 25

26 **6.2.5 Transmission and System Studies**

27

28           NS Power expects regional transmission opportunities to result from the integration of the

29           Maritime Link and subsequent improvements to the Nova Scotia transmission system.

30           The Company will monitor and report on these opportunities during the Action Plan



1 period. Additional system level studies will continue to be required to assess how NS  
2 Power's changing generation asset mix, and potential regional coordination actions, will  
3 affect the need for new transmission system resources.  
4

5 **Transmission and System Studies Actions:**  
6

- 7 • Execute the Maritime Link transmission investments.  
8
- 9 • During 2015 - 2020, conduct additional system studies to evaluate operations with  
10 increased levels of renewable resources that are expected over the next few years.  
11 Include investigation of system requirements with fewer steam units providing  
12 real power operations.  
13
- 14 • Report on the status of such efforts each year in the 10 Year System  
15 Outlook Report.  
16
- 17 • Use Plexos to continue to assess hourly patterns of system need and  
18 resources with respect to operation under higher levels of wind resources  
19 expected over the next few years.  
20
- 21 • Conduct system studies to estimate requirements to ensure reliability with  
22 levels of wind similar to those seen in CRP 7 (medium wind, ~750 MW  
23 installed capacity) and CRP 6 (high wind, ~900 MW of installed  
24 capacity).  
25
- 26 • Consider the effect of the presence of the Maritime Link on system  
27 operations with higher levels of wind, and/or lower levels of connected  
28 coal-fired capacity.  
29

- 1 • Conduct system studies that evaluate the economics, stability and  
2 reliability of the system with accelerated coal unit retirements.  
3
- 4 • Assess the type, level, cost, sequencing, and integration of transmission  
5 system reinforcement requirements that could accompany various coal  
6 plant retirement schedules. This includes the presence of additional  
7 transmission line assets or reinforcement of existing assets; the presence of  
8 dynamic and static reactive power devices including synchronous  
9 condensers (new, or conversions of existing power generators to operate in  
10 this mode); regional coordination opportunities; improved forecasting  
11 techniques; greater use of advanced wind turbine technologies with new  
12 wind; demand response resources; and any other technical innovations that  
13 would affect operations.  
14

#### 15 **6.2.6 Ongoing Analysis of Value of Capacity Contribution towards Resource Adequacy** 16 **Requirements**

17  
18 Strategist used coal plant retirement schedules as an input assumption to the modeling; it  
19 did not determine an economic optimum retirement path as this was not contemplated in  
20 the Candidate Resource Plan process. Sustaining capital needs were also evaluated  
21 outside of the Strategist environment; therefore, additional efforts are required to  
22 determine whether or not certain non-thermal capacity additions can be considered cost-  
23 effective for customers as a contribution towards resource adequacy requirements. The  
24 Candidate Resource Plan method tests characteristics but leaves some optimizations as  
25 actions. This Action Plan element summarizes the actions required to address this issue.  
26

1       **Capacity Contribution Actions:**

- 2
- 3       •       ERIS connected wind resources will be evaluated for firm capacity contribution.  
4             During 2015, NS Power will determine the extent to which ERIS resources can  
5             count as capacity towards resource adequacy during winter peak.  
6
  - 7       •       As part of DSM programming, evaluate the DR resource contributions to  
8             capacity. During 2015-2020, NS Power will continue to assess the availability  
9             and potential for cost-effective Demand Response.  
10

11   **6.2.7 Planning Reserve Margin**

12

13       NS Power maintains a planning reserve margin for system reliability purposes. NS  
14       Power's current planning reserve margin, in compliance with Northeast Power  
15       Coordinating Council (NPCC) criteria, is equal to 20 percent of firm system peak  
16       demand. Enhanced regional cooperation and variable generation integration may impact  
17       planning reserve margin over the Action Plan period. NS Power proposes to keep the  
18       Board and stakeholders advised of any such changes.  
19

20       **Planning Reserve Margin Actions:**

- 21
- 22       •       Report on the ongoing evaluation of the planning reserve margin for the power  
23             system in the 10 Year System Outlook Report.  
24

25   **6.2.8 Regulatory**

26

27       Since the last IRP, there have been numerous regulatory and environmental changes. The  
28       Company does not expect significant additional regulatory changes; however, this  
29       remains a possibility and NS Power wants to ensure the UARB and stakeholders are  
30       informed of the impact of such changes to the IRP planning process.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**Regulatory Actions:**

- Monitor renewable and emissions related legislative/regulatory developments.
- Report to the UARB on legislative/regulatory changes that may have a material impact on the Action Plan – one update to be sent in Q3 2016.

**6.2.9 IRP Planning and Modeling Process Improvement**

**IRP and Planning Process Actions:**

- During 2015, create a plan for an update to the IRP process during the 2016-2018 ENSC performance period to reflect then-current performance and then-current net load forecasts for firm peak and annual energy. Report to the UARB by the end of 2015 on this.
- Review model use for the next IRP. Consider how Strategist, Plexos, and power flow modeling tools can be best utilized for the next round of integrated resource planning.
  - Strategist – analyze strengths and weaknesses.
  - Plexos – analyze strengths and weaknesses.
  - Power flow modeling tools – analyze their role in assessing capital requirements for system stability and related transmission reinforcement.

1 **6.3 Strategic Resource Plan Decision Paths**

2  
3 As with all long-term planning exercises or forecasts in general, there are considerable  
4 uncertainties within the planning period. One of the goals of the IRP is to produce a path  
5 that maintains enough flexibility to allow for such uncertainty. As part of its Analysis  
6 Plan, the Company considered a number of possible deviations from the basic  
7 assumptions to enable it optionality in the event of a different planning horizon. The  
8 table below references potential triggers that could cause the Company to alter its  
9 planning path and identifies the CRPs which it would consider under such circumstances.

10

Trigger	2014 IRP World	Resource Plan to Consider
Higher sustained load growth	High Load World	CRP 21
High DSM performance	Reference World	CRP 5
Low DSM performance	Reference World	CRP 1
More stringent environmental requirements introduced	Reference World	CRP 2
	High Load World	CRP 21
Additional RES requirement	Reference World	CRP 3 (medium wind)
		CRP 8 (high wind)

11  
12 **6.4 Risk and Opportunity Analysis**

13  
14 The following sections outline the potential risks and opportunities that the Company  
15 envisions over the planning horizon. These are items that NS Power will continue to  
16 evaluate over the Action Plan Period and consider as part of subsequent IRPs.

1 **6.4.1 Retirements**

2  
3 Early steam fleet retirement did not show significant benefit when compared to maximum  
4 steam fleet utilization. The risk associated with early steam fleet retirement is the  
5 reduced system flexibility while attempting to integrate approximately 600 MW of  
6 variable generation and significant quantity of DSM. If DSM programs do not deliver  
7 energy and peak reductions as forecasted, early steam fleet retirement scenarios will call  
8 for new capacity to be built in order to maintain system reliability.

9  
10 ~~We acknowledge~~NS Power acknowledges that the load-following service envisioned for  
11 many of NS Power's conventional steam units will introduce new maintenance risks that  
12 will be addressed through asset management strategies.

13  
14 **6.4.2 DSM**

15  
16 High investment in DSM in the early years poses a risk of increasing pressure on power  
17 rates in the near term, while the risk of underperformance associated with unprecedented  
18 levels of DSM may require additional investment in firm capacity, exerting further  
19 pressure on power rates.

20  
21 Low investment in DSM in the early years carries the risk of missed opportunity to  
22 reduce demand and provide immediate fuel cost savings in the near term, while providing  
23 extended benefits for the life of the program.

24  
25 Suboptimal investment in DSM coupled with the potential loss of industrial load poses a  
26 challenge with taking advantage of Maritime Link surplus energy and is showing higher  
27 amounts of wind energy curtailment and uneconomic exports.

1 **6.4.3 Environmental regulations**

2  
3 There are no legislated environmental regulations past year 2030. In the IRP simulations,  
4 the Company extrapolated the most likely set of emissions limits based on the existing  
5 regulations, and tested two sensitivities around the base line. The risk associated with  
6 uncertain environmental regulations in the long term stresses the importance of  
7 maintaining the flexibility of the existing diverse generation fleet and planning additional  
8 supply and demand side resources as required.

9  
10 While different emission sensitivities were tested this analysis was conducted with only  
11 base case fuel and energy prices and the impact of variable fuel and energy pricing on  
12 emission compliance costs was not evaluated in this IRP.

13  
14 **6.4.4 Flu Gas Desulphurization**

15  
16 More so than in the previous IRPs, FGD emerged as optimal even with the assumed  
17 relatively high price of high sulfur coal. With decreasing SO<sub>2</sub> emissions caps, an FGD  
18 could provide an opportunity to take advantage of low priced high sulfur coal which can  
19 help stabilize power rates and provide an attractive incentive for retention of present  
20 industrial load and even attracting new industrial customers. Due the single stack shared  
21 by two generating units configuration, Lingan power station is an ideal site for an FGD  
22 providing most value for a single installation.

23  
24 The risk associated with building an FGD lies partly in the availability of sufficient  
25 quantity of relatively inexpensive high sulfur coal product, and partly in the uncertainty  
26 with CO<sub>2</sub> air emissions regulations in the future.

1 **6.4.5 Resource Incompatibility and Unintended Competition**

2  
3 Nova Scotia climate causes the phenomenon of low overnight system demand, followed  
4 by relatively high morning demand, with significant seasonal variations. Due to system  
5 stability and security issues, minimum amount of high inertia steam generation is  
6 required to be online, which in low load periods causes wind curtailment and sub optimal  
7 utilization of Maritime Link off-peak surplus energy. Chronological hourly system  
8 simulations have shown high levels of wind curtailment and uneconomic energy exports,  
9 coupled with low utilization of Maritime Link available off-peak surplus energy, in  
10 resource plans containing additional wind generation and high levels of DSM.  
11 Investment in wind resources and DSM programs will have to be designed not to exert  
12 further downward pressure on low load periods and not to compete with Maritime Link  
13 surplus energy utilization and with each other. DSM programs may have to include  
14 demand response in order to be optimal.

15  
16 **6.4.6 Firm Capacity and ERIS Wind Generation**

17  
18 Arising from the Cost of Service proceedings was an action for NS Power to evaluate the  
19 contribution to firm capacity which is available from Energy Resource Interconnection  
20 Service (ERIS) wind projects. The concept around ERIS is that the generation  
21 interconnection customer can operate up to its full rated output only if transmission  
22 capacity is available. Under peak conditions, many transmission corridors are operating  
23 at rated transfer capacity, leaving no transmission capability available for ERIS generator  
24 and requiring a down dispatch or curtailment of that generator. Network Resource  
25 Interconnection Service generation projects are considered firm assets as transmission  
26 capacity is available at all times for the facility to deliver its full rated capacity to the  
27 power system.

28  
29 On the NS Power electric power system, at the present level of wind integration,  
30 curtailment of ERIS wind projects is not frequently observed leaving the impression that



1 there is adequate transmission capacity to accommodate both NRIS and ERIS projects  
2 even during peak operating conditions. As most ERIS projects on the NS Power system  
3 are recently added renewable electricity generators they receive priority environmental  
4 dispatch to assist NS Power in meeting the requirements of the Nova Scotia Renewable  
5 Electricity Regulations. What often goes unnoticed is the down dispatch or the bottling  
6 of NRIS generating capacity to allow the renewable projects to operate and meet  
7 production targets. In other words, firm generation is being dispatched down in order to  
8 allow ERIS wind generation on the system, at times when all firm generation capacity is  
9 not required. On most occasions the down dispatch of firm resources has no bearing on  
10 the power system, but this does become a consideration in the planning of the  
11 contribution of these ERIS projects to firm system capacity. If ERIS projects operate on  
12 peak system conditions only when NRIS generation is restricted to accommodate the  
13 renewables, then the full capacity of the NRIS resources and the ERIS resources cannot  
14 be counted towards the system's firm capacity.

15  
16 ERIS generation is considered non-firm energy under the Open Access Transmission  
17 Tariff (OATT) and an ERIS generation unit cannot be assigned as a Network Resource  
18 by a Network Service Customer as per Section III of the Tariff. Despite this, the NS  
19 Power was requested to evaluate the possible contribution to firm capacity that could be  
20 counted from ERIS wind projects.

21  
22 The Nova Scotia Power System Operator (NSPSO) examined the following wind  
23 powered generation facilities which are designated ERIS on the NS Power transmission  
24 System:

- 25
- 26 • 89N-Nuttby Mountain 49.5 MW
- 27 • 91N-Dalhousie Mountain 50.0 MW
- 28 • 93N-Glen Dhu 62.0 MW
- 29

1 Any such evaluation is subject to power system configuration and the NSPSO examined  
2 conditions anticipated after the integration of the Maritime Link. The particulars of these  
3 system modeling assumptions are summarized in Appendix M. All design contingencies  
4 as described by NPCC and the North American Electricity Reliability Corporation  
5 (NERC) criteria were tested for the assumed system configuration. No violations of  
6 voltage, stability, or thermal overloads were found under these tested conditions for the  
7 wind projects noted above.

8  
9 Accordingly it can be concluded that, given the study assumptions, the transmission  
10 connected ERIS wind projects considered in this study would not likely be curtailed if  
11 they are operating at 17 percent of their nameplate capacity. It is important to note that  
12 this is not a derivation of the Capacity Value of the wind which is a consideration  
13 discussed in Section 3.6 of this report. It should also be noted that this evaluation is  
14 limited to the projects studied and is not applicable to all future ERIS projects. It is also  
15 possible that if system development deviates from the conditions assumed in Appendix M  
16 that these study outcomes could change.

17  
18 This analysis does not constitute the System Impact Study necessary to change the  
19 designation of any wind project from ERIS to NRIS. For these installations to be  
20 designated as Network Resource Interconnection Service (NRIS), and therefore be  
21 eligible to be counted as Network Resources, an application for NRIS would be required  
22 via the Generator Interconnection Procedures (GIP) and the appropriate procedures  
23 would be followed. This work suggests that a portion of the installed projects could be  
24 counted towards the firm system generating capacity, but it isn't clear how this could be  
25 handled within the provisions of the Tariff. NS Power is proposing an Action Plan item  
26 to determine how to work through these Tariff and GIP related issues.

1 **7.0 GLOSSARY OF TERMS**

2

ACI	Activated Carbon Injection
BSD	Burnside
CAES	Compressed Air Energy Storage
CC	Combined Cycle
CCS	Carbon Capture and Storage
CO <sub>2</sub>	Carbon Dioxide
COMFIT	Community Feed-In Tariff
CRP	Candidate Resource Plan
CT	Combustion Turbine
CV	Capacity Value
DR	Demand Response
DSM	Demand Side Management
ERIS	Energy Resource Interconnection Service
FGD	Flue Gas Desulfurization
GHG	Greenhouse Gas
HFO	Heavy Fuel Oil
Hg	Mercury
HRSG	Heat Recovery Steam Generator
HS	High Sulfur
IGCC	Integrated Gasification Combined Cycle
IPP	Independent Power Producer
IRP	Integrated Resource Plan
LFO	Light Fuel Oil
LIN	Lingan
LS	Low Sulfur
ML	Maritime Link
MS	Medium Sulfur
NB	New Brunswick
NG	Natural Gas
NO <sub>x</sub>	Oxides of Nitrogen (NO and NO <sub>2</sub> )

## 2014 IRP Final Report

---

NPV	Net Present Value
NRIS	Network Resource Interconnection Service
NS	Nova Scotia
NSPI	Nova Scotia Power Incorporated
PAC	Powder Activated Carbon
PC	Pulverized Coal
PHP	Port Hawkesbury Paper
POA	Point Aconi
POT	Point Tupper
PPA	Power Purchase Agreement
RES	Renewable Electricity Standard
RM	Reserve Margin
SO <sub>2</sub>	Sulfur Dioxide
TRE	Trenton
TRL	Technology Readiness Level
TUC	Tuft's Cove
WRC	Wreck Cove

1