

## **ELECTRICAL INSPECTION BULLETIN**

**B-06-112**

**Maximum Length of Utility Triplex Service Conductor for Mobile Homes**



*(Effective 11/01/2008)*

---

Presently, the maximum length of triplex service conductor to mobile homes is 23 meters.

Newer mobile homes built in accordance with CAN/CSA-Z240MH Series 92 standard have been equipped with an improved mast support system.

Effective 96-12-02, the maximum unsupported triplex utility service drop, to mobile homes, equipped with a factory installed service raceway support member, meeting or exceeding the above-noted standard and mounted on an acceptable block or concrete foundation, may with utility approval, be increased to a maximum of 38 meters.

Refer to Nova Scotia Power Inc. Utility Service Requirement document drawings SS-ED-24M and SS-ED-25M