

ELECTRICAL INSPECTION BULLETIN

B-06-206

Length of Service Entrance Conductors For Mobile / Mini and Factory Built Homes



(Effective 02/01/2009)

When applied to a mobile / mini and factory built home, for the purpose of Rule 6-206 “As close as practicable” shall not be more than 7.5m (25 ft.) The 7.5 m allowance shall only apply to these particular type homes that are built to CSA Z240 standard.

The 7.5m distance shall be measured along the raceway length from the point where the conductors are considered to be enclosed by the building structure (skirted area) to the point where they terminate on the line side of the consumer service box.

The 7.5 metre allowance is not automatic but may be applied at the discretion of the wiring inspector.

This relaxation only applies to mobile / mini and factory built homes built to CSA Z240 when not placed on a permanent foundation. Modular homes built to CSA Z277 and homes built to CSA Z240 placed on a permanent foundation shall follow the “as close as practicable “ rule which is defined as not more than 3 m. as per Nova Scotia Department of Labour and Workforce Development Electrical Bulletin 2007-01.